

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P222396

Luminaire Tested: **LSSQ2B10NFL259727D010 2LBDL*WH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P222396
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (155)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQ2B10NFL259727D010 2LBDL*WH
Description: 1000 Lumen, 2inch Portfolio LED Cylinder
NARROW FLOOD OPTIC
LENSED SPUN ROUND TRIM WITH WHEAT HAZE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 665.8 lumens
Efficiency: N/A
Efficacy: 64.6 lumens/watt
Spacing Criteria (0/90/45): 0.39 / 0.39 / 0.35
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P222396

CATALOG NUMBER: LSSQ2B10NFL259727D010 2LBDL*WH

Luminous Intensity Polar Plot





TEST NUMBER: P222396

CATALOG NUMBER: LSSQ2B10NFL259727D010 2LBDL*WH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10		50	30	10			50	30	10			50
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111			106	106	106			102
1	115	113	112	110	113	111	110	108		107	106	105			104	103	102			100
2	112	109	106	104	110	107	104	102		104	102	100			101	99	98			98
3	109	105	101	99	107	103	100	98		101	98	96			99	97	95			96
4	106	101	97	95	104	100	97	94		98	95	93			96	94	92			95
5	103	98	94	91	102	97	94	91		95	92	90			94	91	89			93
6	101	95	91	89	99	94	91	88		93	90	88			92	89	87			91
7	98	92	89	86	97	92	88	86		91	88	85			90	87	85			89
8	96	90	86	84	95	90	86	84		89	86	83			88	85	83			87
9	94	88	84	82	93	88	84	82		87	84	82			86	83	81			85
10	92	86	82	80	91	86	82	80		85	82	80			84	82	80			84

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1529978
5°	1412681
10°	956204
15°	325299
20°	119498
25°	63339
30°	32561
35°	15179
40°	4955
45°	2520
50°	1205
55°	473
60°	542
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P222396

CATALOG NUMBER: LSSQ2B10NFL259727D010 2LBDL*WH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	309.1	46.4
10°-20°	259.9	39.0
20°-30°	71.3	10.7
30°-40°	20.8	3.1
40°-50°	3.8	0.6
50°-60°	0.9	0.1
60°-70°	0.1	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	640.2	96.2
0°-40°	661.0	99.3
0°-60°	665.7	100.0
0°-90°	665.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	665.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3950	
5°	3633	309
15°	811	260
25°	148	71
35°	32	21
45°	5	4
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P222396

CATALOG NUMBER: LSSQ2B10NFL259727D010 2LBDL*WH

CANDELA DISTRIBUTION (FULL):

	0°
0°	3949.9
1°	3927.0
2°	3886.3
3°	3828.0
4°	3748.0
5°	3633.2
6°	3476.4
7°	3280.4
8°	3041.0
9°	2758.3
10°	2431.1
11°	2072.4
12°	1699.2
13°	1343.1
14°	1039.5
15°	811.2
17.5°	457.8
20°	289.9
22.5°	206.6
25°	148.2
27.5°	104.9
30°	72.8
32.5°	51.2
35°	32.1
37.5°	13.1
40°	9.8
42.5°	7.2
45°	4.6
47.5°	2.6
50°	2.0
52.5°	1.3
55°	0.7
57.5°	0.7
60°	0.7
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P222396

CATALOG NUMBER: LSSQ2B10NFL259727D010 2LBDL*WH

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°	0.0
87.5°	0.0



(END OF REPORT)