

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P223587

Luminaire Tested: **LSR2B10SP159730D010 2LBDC*MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P223587
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (150)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR2B10SP159730D010 2LBDC*MW
Description: 1000 Lumen, 2inch Portfolio LED Cylinder
SPOT OPTIC
CAST ROUND TRIM WITH MATTE WHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 443.0 lumens
Efficiency: N/A
Efficacy: 43.0 lumens/watt
Spacing Criteria (0/90/45): 0.24 / 0.24 / 0.23
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P223587

CATALOG NUMBER: LSR2B10SP159730D010 2LBDC*MW

Luminous Intensity Polar Plot





TEST NUMBER: P223587

CATALOG NUMBER: LSR2B10SP159730D010 2LBDC*MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	116	114	112	111	113	112	110	109	108	107	106		104	103	103		101
2	113	110	107	105	111	108	106	104	105	103	102		102	101	100		100
3	110	106	103	101	108	105	102	100	102	100	98		100	99	97		98
4	108	103	100	97	106	102	99	97	100	98	96		98	96	95		97
5	105	101	97	95	104	100	97	94	98	96	94		97	95	93		95
6	103	98	95	93	102	98	95	92	96	94	92		95	93	91		94
7	101	96	93	91	100	96	93	90	95	92	90		94	91	90		93
8	100	94	91	89	99	94	91	89	93	90	89		92	90	88		92
9	98	93	90	88	97	92	89	87	92	89	87		91	89	87		90
10	96	91	88	86	96	91	88	86	90	88	86		90	87	86		89

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2128699
5°	1538855
10°	447993
15°	157196
20°	67313
25°	30302
30°	11718
35°	5816
40°	3893
45°	2520
50°	1386
55°	1013
60°	620
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P223587

CATALOG NUMBER: LSR2B10SP159730D010 2LBDC*MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	280.1	63.2
10°-20°	113.9	25.7
20°-30°	35.0	7.9
30°-40°	8.6	1.9
40°-50°	3.6	0.8
50°-60°	1.5	0.3
60°-70°	0.3	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	429.0	96.8
0°-40°	437.6	98.8
0°-60°	442.7	99.9
0°-90°	443.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	443.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5496	
5°	3958	280
15°	392	114
25°	71	35
35°	12	9
45°	5	4
55°	2	2
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P223587

CATALOG NUMBER: LSR2B10SP159730D010 2LBDC*MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	5495.6
1°	5411.7
2°	5206.8
3°	4880.3
4°	4453.6
5°	3957.7
6°	3398.6
7°	2791.7
8°	2176.4
9°	1601.1
10°	1139.0
11°	816.3
12°	613.8
13°	499.8
14°	437.4
15°	392.0
17.5°	241.8
20°	163.3
22.5°	109.4
25°	70.9
27.5°	43.1
30°	26.2
32.5°	16.9
35°	12.3
37.5°	10.0
40°	7.7
42.5°	6.2
45°	4.6
47.5°	3.1
50°	2.3
52.5°	2.3
55°	1.5
57.5°	1.5
60°	0.8
62.5°	0.8
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P223587

CATALOG NUMBER: LSR2B10SP159730D010 2LBDC*MW

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°	0.0
87.5°	0.0



(END OF REPORT)