

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P#

Luminaire Tested: **LSSQWM2B10WFL559730D010 2LBDL*B**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P#
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14809)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQWM2B10WFL559730D010 2LBDL*B
Description: 1000 Lumen, 2inch Portfolio LED Cylinder
WIDE FLOOD OPTIC
LENSED SPUN ROUND TRIM WITH BLACK FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 659.1 lumens
Efficiency: N/A
Efficacy: 64.0 lumens/watt
Spacing Criteria (0/90/45): 0.79 / 0.79 / 0.84
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B10WFL559730D010 2LBDL*B

Luminous Intensity Polar Plot





TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B10WFL559730D010 2LBDL*B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20							
RC	80				70				50				30				10				0			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																								
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100						
1	113	111	108	106	111	109	106	104	104	103	101	101	99	98	97	96	95	93						
2	108	103	99	95	106	101	97	94	98	95	92	95	92	90	92	90	88	87						
3	102	96	91	87	100	94	90	86	92	88	85	89	86	83	87	84	82	80						
4	97	89	84	79	95	88	83	79	86	82	78	84	80	77	82	79	76	75						
5	92	83	78	73	90	83	77	73	81	76	72	79	75	72	77	74	71	69						
6	87	78	72	68	86	77	72	68	76	71	67	74	70	67	73	69	66	65						
7	83	73	67	63	81	73	67	63	71	66	63	70	66	62	69	65	62	60						
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57						
9	75	65	59	55	74	65	59	55	64	59	55	63	58	55	62	58	55	53						
10	71	62	56	52	70	61	56	52	60	55	52	60	55	52	59	55	51	50						

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	313750
5°	311760
10°	290350
15°	254601
20°	219953
25°	187068
30°	148404
35°	102422
40°	64318
45°	38345
50°	22236
55°	11210
60°	697
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B10WFL559730D010 2LBDL*B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	74.5	11.3
10°-20°	177.0	26.9
20°-30°	199.2	30.2
30°-40°	136.9	20.8
40°-50°	56.8	8.6
50°-60°	14.7	2.2
60°-70°	0.1	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	450.6	68.4
0°-40°	587.5	89.1
0°-60°	659.0	100.0
0°-90°	659.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	659.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	810	
5°	802	74
15°	635	177
25°	438	199
35°	217	137
45°	70	57
55°	17	15
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B10WFL559730D010 2LBDL*B

CANDELA DISTRIBUTION (FULL):

0°	
0°	810.0
2.5°	809.1
5°	801.8
7.5°	777.8
10°	738.2
12.5°	688.4
15°	634.9
17.5°	580.6
20°	533.6
22.5°	487.5
25°	437.7
27.5°	387.1
30°	331.8
32.5°	272.8
35°	216.6
37.5°	168.6
40°	127.2
42.5°	95.8
45°	70.0
47.5°	50.7
50°	36.9
52.5°	25.8
55°	16.6
57.5°	5.5
60°	0.9
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)