

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P225130

Luminaire Tested: **LSRWM2B10FL408040D010 2LBD*GPH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P225130
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14831)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSRWM2B10FL408040D010 2LBD*GPH
Description: 1000 Lumen, 2inch Portfolio LED Cylinder
FLOOD OPTIC
SPUN ROUND TRIM WITH GRAPHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1088.7 lumens
Efficiency: N/A
Efficacy: 105.7 lumens/watt
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.59
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P225130

CATALOG NUMBER: LSRWM2B10FL408040D010 2LBD*GPH

Luminous Intensity Polar Plot





TEST NUMBER: P225130

CATALOG NUMBER: LSRWM2B10FL408040D010 2LBD*GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			50
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			102
1	114	112	110	108		112	110	108	106		106	104	103			102	101	100			99
2	110	106	102	100		108	104	101	98		101	99	96			98	96	94			95
3	106	100	96	93		104	99	95	92		96	93	91			94	92	89			92
4	102	95	91	87		100	94	90	87		92	89	86			90	87	85			89
5	98	91	86	83		96	90	85	82		88	84	81			87	83	81			85
6	94	87	82	78		93	86	81	78		85	81	78			83	80	77			82
7	91	83	78	75		89	82	78	74		81	77	74			80	76	74			79
8	87	80	75	71		86	79	74	71		78	74	71			77	73	71			76
9	84	76	72	68		83	76	71	68		75	71	68			74	70	68			73
10	81	73	69	65		80	73	68	65		72	68	65			72	68	65			71

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	987616
5°	967670
10°	859840
15°	674579
20°	453714
25°	263998
30°	132213
35°	61709
40°	28771
45°	12161
50°	5845
55°	3782
60°	2169
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P225130

CATALOG NUMBER: LSRWM2B10FL408040D010 2LBD*GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	227.8	20.9
10°-20°	456.6	41.9
20°-30°	288.7	26.5
30°-40°	89.8	8.2
40°-50°	20.0	1.8
50°-60°	5.1	0.5
60°-70°	0.7	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	973.2	89.4
0°-40°	1063.0	97.6
0°-60°	1088.0	99.9
0°-90°	1088.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1088.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2550	
5°	2489	228
15°	1682	457
25°	618	289
35°	130	90
45°	22	20
55°	6	5
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P225130

CATALOG NUMBER: LSRWM2B10FL408040D010 2LBD*GPH

CANDELA DISTRIBUTION (FULL):

0°	
0°	2549.7
2.5°	2538.6
5°	2488.7
7.5°	2370.7
10°	2186.1
12.5°	1952.9
15°	1682.2
17.5°	1389.4
20°	1100.7
22.5°	841.1
25°	617.7
27.5°	433.1
30°	295.6
32.5°	195.7
35°	130.5
37.5°	87.4
40°	56.9
42.5°	34.7
45°	22.2
47.5°	15.3
50°	9.7
52.5°	6.9
55°	5.6
57.5°	4.2
60°	2.8
62.5°	1.4
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)