

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P225136

Luminaire Tested: **LSR2B10FL409040D010 2LBD*GPH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P225136
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14831)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR2B10FL409040D010 2LBD*GPH
Description: 1000 Lumen, 2inch Portfolio LED Cylinder
FLOOD OPTIC
SPUN ROUND TRIM WITH GRAPHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 884.6 lumens
Efficiency: N/A
Efficacy: 85.9 lumens/watt
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.59
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P225136

CATALOG NUMBER: LSR2B10FL409040D010 2LBD*GPH

Luminous Intensity Polar Plot





TEST NUMBER: P225136

CATALOG NUMBER: LSR2B10FL409040D010 2LBD*GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	114	112	110	108		112	110	108	106		106	104	103		102	101	100		99	98	97
2	110	106	102	100		108	104	101	98		101	99	96		98	96	94		95	94	92
3	106	100	96	93		104	99	95	92		96	93	91		94	92	89		92	90	88
4	102	95	91	87		100	94	90	87		92	89	86		90	87	85		89	86	84
5	98	91	86	83		96	90	85	82		88	84	81		87	83	81		85	82	80
6	94	87	82	78		93	86	81	78		85	81	78		83	80	77		82	79	77
7	91	83	78	75		89	82	78	74		81	77	74		80	76	74		79	76	73
8	87	80	75	71		86	79	74	71		78	74	71		77	73	71		76	73	70
9	84	76	72	68		83	76	71	68		75	71	68		74	70	68		73	70	68
10	81	73	69	65		80	73	68	65		72	68	65		72	68	65		71	67	65

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	802465
5°	786244
10°	698657
15°	548141
20°	368635
25°	214507
30°	107434
35°	50123
40°	23361
45°	9860
50°	4761
55°	3039
60°	1782
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P225136

CATALOG NUMBER: LSR2B10FL409040D010 2LBD*GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	185.1	20.9
10°-20°	371.0	41.9
20°-30°	234.6	26.5
30°-40°	73.0	8.3
40°-50°	16.2	1.8
50°-60°	4.1	0.5
60°-70°	0.5	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	790.7	89.4
0°-40°	863.7	97.6
0°-60°	884.0	99.9
0°-90°	884.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	884.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2072	
5°	2022	185
15°	1367	371
25°	502	235
35°	106	73
45°	18	16
55°	4	4
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P225136

CATALOG NUMBER: LSR2B10FL409040D010 2LBD*GPH

CANDELA DISTRIBUTION (FULL):

0°	
0°	2071.7
2.5°	2062.7
5°	2022.1
7.5°	1926.2
10°	1776.3
12.5°	1586.8
15°	1366.9
17.5°	1128.9
20°	894.3
22.5°	683.4
25°	501.9
27.5°	351.9
30°	240.2
32.5°	159.0
35°	106.0
37.5°	71.1
40°	46.2
42.5°	28.2
45°	18.0
47.5°	12.4
50°	7.9
52.5°	5.6
55°	4.5
57.5°	3.4
60°	2.3
62.5°	1.1
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)