

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P#

Luminaire Tested: **LSSQWM2B15WFL559035D010 2LBD\*GPH**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P#  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14806)  
Test Lab: INNOVATION CENTER (G1)  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSSQWM2B15WFL559035D010 2LBD\*GPH  
Description: 1500 Lumen, 2inch Portfolio LED Cylinder  
WIDE FLOOD OPTIC  
SPUN ROUND TRIM WITH GRAPHITE FINISH  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1066.7 lumens  
Efficiency: N/A  
Efficacy: 74.6 lumens/watt  
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.83  
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')  
CIE Type: Direct


Input Watts (W): 14.3  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B15WFL559035D010 2LBD\*GPH

### Luminous Intensity Polar Plot





TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B15WFL559035D010 2LBD\*GPH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |  |     |     |     |     |  |     |     |     |  |     |     |     |  |     |     |     |
|-----|-----|-----|-----|-----|--|-----|-----|-----|-----|--|-----|-----|-----|--|-----|-----|-----|--|-----|-----|-----|
| RF  | 20  |     |     |     |  | 20  |     |     |     |  | 20  |     |     |  |     | 20  |     |  |     |     | 20  |
| RC  | 80  |     |     |     |  | 70  |     |     |     |  | 50  |     |     |  |     | 30  |     |  |     |     | 10  |
| RW  | 70  | 50  | 30  | 10  |  | 70  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  | 30  | 10  |
| RCR |     |     |     |     |  |     |     |     |     |  |     |     |     |  |     |     |     |  |     |     |     |
| 0   | 119 | 119 | 119 | 119 |  | 116 | 116 | 116 | 116 |  | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 | 102 | 102 |
| 1   | 113 | 111 | 108 | 106 |  | 111 | 108 | 106 | 104 |  | 104 | 103 | 101 |  | 101 | 99  | 98  |  | 97  | 96  | 95  |
| 2   | 108 | 103 | 99  | 95  |  | 105 | 101 | 97  | 94  |  | 98  | 95  | 92  |  | 95  | 92  | 90  |  | 92  | 90  | 88  |
| 3   | 102 | 95  | 90  | 86  |  | 100 | 94  | 89  | 86  |  | 91  | 88  | 84  |  | 89  | 86  | 83  |  | 87  | 84  | 82  |
| 4   | 97  | 89  | 83  | 79  |  | 95  | 88  | 83  | 79  |  | 86  | 81  | 78  |  | 84  | 80  | 77  |  | 82  | 79  | 76  |
| 5   | 92  | 83  | 77  | 73  |  | 90  | 82  | 77  | 72  |  | 80  | 75  | 72  |  | 79  | 74  | 71  |  | 77  | 73  | 70  |
| 6   | 87  | 78  | 72  | 67  |  | 85  | 77  | 71  | 67  |  | 75  | 70  | 67  |  | 74  | 70  | 66  |  | 73  | 69  | 66  |
| 7   | 83  | 73  | 67  | 63  |  | 81  | 72  | 67  | 62  |  | 71  | 66  | 62  |  | 70  | 65  | 62  |  | 69  | 65  | 61  |
| 8   | 78  | 69  | 63  | 58  |  | 77  | 68  | 62  | 58  |  | 67  | 62  | 58  |  | 66  | 61  | 58  |  | 65  | 61  | 58  |
| 9   | 75  | 65  | 59  | 55  |  | 74  | 64  | 59  | 55  |  | 63  | 58  | 54  |  | 62  | 58  | 54  |  | 62  | 57  | 54  |
| 10  | 71  | 61  | 55  | 51  |  | 70  | 61  | 55  | 51  |  | 60  | 55  | 51  |  | 59  | 54  | 51  |  | 58  | 54  | 51  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 508237 |
| 5°  | 502674 |
| 10° | 464591 |
| 15° | 406865 |
| 20° | 350786 |
| 25° | 299471 |
| 30° | 236873 |
| 35° | 163894 |
| 40° | 106084 |
| 45° | 64365  |
| 50° | 37663  |
| 55° | 21070  |
| 60° | 8057   |
| 65° | 0      |
| 70° | 0      |
| 75° | 0      |
| 80° | 0      |
| 85° | 0      |



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B15WFL559035D010 2LBD\*GPH

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 119.8  | 11.2      |
| 10°-20°   | 282.9  | 26.5      |
| 20°-30°   | 318.3  | 29.8      |
| 30°-40°   | 219.5  | 20.6      |
| 40°-50°   | 94.8   | 8.9       |
| 50°-60°   | 29.4   | 2.8       |
| 60°-70°   | 2.0    | 0.2       |
| 70°-80°   | 0.0    | 0.0       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 721.0  | 67.6      |
| 0°-40°    | 940.5  | 88.2      |
| 0°-60°    | 1064.7 | 99.8      |
| 0°-90°    | 1066.7 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 1066.7 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 1312 |      |
| 5°  | 1293 | 120  |
| 15° | 1015 | 283  |
| 25° | 701  | 318  |
| 35° | 347  | 220  |
| 45° | 118  | 95   |
| 55° | 31   | 29   |
| 65° | 0    | 2    |
| 75° | 0    | 0    |
| 85° | 0    | 0    |
| 90° | 0    |      |



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B15WFL559035D010 2LBD\*GPH

**CANDELA DISTRIBUTION (FULL):**

|       | 0°     |
|-------|--------|
| 0°    | 1312.1 |
| 2.5°  | 1309.2 |
| 5°    | 1292.8 |
| 7.5°  | 1249.7 |
| 10°   | 1181.2 |
| 12.5° | 1100.9 |
| 15°   | 1014.6 |
| 17.5° | 928.3  |
| 20°   | 851.0  |
| 22.5° | 776.6  |
| 25°   | 700.7  |
| 27.5° | 620.4  |
| 30°   | 529.6  |
| 32.5° | 434.4  |
| 35°   | 346.6  |
| 37.5° | 272.2  |
| 40°   | 209.8  |
| 42.5° | 157.7  |
| 45°   | 117.5  |
| 47.5° | 86.3   |
| 50°   | 62.5   |
| 52.5° | 44.6   |
| 55°   | 31.2   |
| 57.5° | 20.8   |
| 60°   | 10.4   |
| 62.5° | 3.0    |
| 65°   | 0.0    |
| 67.5° | 0.0    |
| 70°   | 0.0    |
| 72.5° | 0.0    |
| 75°   | 0.0    |
| 77.5° | 0.0    |
| 80°   | 0.0    |
| 82.5° | 0.0    |
| 85°   | 0.0    |
| 87.5° | 0.0    |
| 90°   | 0.0    |



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)