

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P224201

Luminaire Tested: **LSSQWM2B05SP158027D010 2LBDLC*MMS**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P224201
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (150)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQWM2B05SP158027D010 2LBDLC*MMS
Description: 500 Lumen, 2inch Portfolio LED Cylinder
SPOT OPTIC
LENSED CAST ROUND TRIM WITH MATTE METALLIC SILVER
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 374.0 lumens
Efficiency: N/A
Efficacy: 51.2 lumens/watt
Spacing Criteria (0/90/45): 0.24 / 0.24 / 0.23
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 7.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P224201

CATALOG NUMBER: LSSQWM2B05SP158027D010 2LBDLC*MMS

Luminous Intensity Polar Plot





TEST NUMBER: P224201

CATALOG NUMBER: LSSQWM2B05SP158027D010 2LBDLC*MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			0
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			100
1	116	114	112	111		113	112	110	109		108	107	106			104	103	103			98
2	113	110	107	105		111	108	106	104		105	103	102			102	101	100			96
3	110	106	103	101		108	105	102	100		102	100	98			100	98	97			94
4	108	103	100	97		106	102	99	97		100	98	96			98	96	95			93
5	105	101	97	95		104	100	97	94		98	96	94			97	95	93			91
6	103	98	95	93		102	98	95	92		96	94	92			95	93	91			90
7	101	96	93	91		100	96	93	90		95	92	90			94	91	90			88
8	100	94	91	89		99	94	91	89		93	90	89			92	90	88			87
9	98	93	90	88		97	92	89	87		92	89	87			91	89	87			86
10	96	91	88	86		96	91	88	86		90	88	86			90	87	86			85

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1797130
5°	1299144
10°	378218
15°	132694
20°	56802
25°	25558
30°	9885
35°	4918
40°	3287
45°	2136
50°	1205
55°	878
60°	542
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P224201

CATALOG NUMBER: LSSQWM2B05SP158027D010 2LBDLC*MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	236.4	63.2
10°-20°	96.2	25.7
20°-30°	29.5	7.9
30°-40°	7.3	1.9
40°-50°	3.0	0.8
50°-60°	1.3	0.4
60°-70°	0.3	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	362.1	96.8
0°-40°	369.4	98.8
0°-60°	373.8	99.9
0°-90°	374.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	374.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4640	
5°	3341	236
15°	331	96
25°	60	30
35°	10	7
45°	4	3
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P224201

CATALOG NUMBER: LSSQWM2B05SP158027D010 2LBDLC*MMS

CANDELA DISTRIBUTION (FULL):

	0°
0°	4639.6
1°	4568.8
2°	4395.8
3°	4120.2
4°	3760.0
5°	3341.2
6°	2869.2
7°	2356.9
8°	1837.4
9°	1351.7
10°	961.6
11°	689.2
12°	518.2
13°	422.0
14°	369.3
15°	330.9
17.5°	204.2
20°	137.8
22.5°	92.3
25°	59.8
27.5°	36.4
30°	22.1
32.5°	14.3
35°	10.4
37.5°	8.5
40°	6.5
42.5°	5.2
45°	3.9
47.5°	2.6
50°	2.0
52.5°	2.0
55°	1.3
57.5°	1.3
60°	0.7
62.5°	0.7
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P224201

CATALOG NUMBER: LSSQWM2B05SP158027D010 2LBDLC*MMS

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°	0.0
87.5°	0.0



(END OF REPORT)