

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P#

Luminaire Tested: **LSSQWM2B05WFL558030D010 2LBDLC*MB**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P#
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14809)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQWM2B05WFL558030D010 2LBDLC*MB
Description: 500 Lumen, 2inch Portfolio LED Cylinder
WIDE FLOOD OPTIC
LENSED CAST ROUND TRIM WITH MATTE BLACK FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 640.0 lumens
Efficiency: N/A
Efficacy: 87.7 lumens/watt
Spacing Criteria (0/90/45): 0.79 / 0.79 / 0.84
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 7.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL558030D010 2LBDLC*MB

Luminous Intensity Polar Plot





TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL558030D010 2LBDLC*MB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			50
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			102
1	113	111	108	106		111	109	106	104		104	103	101			101	99	98			97
2	108	103	99	95		106	101	97	94		98	95	92			95	92	90			92
3	102	96	91	87		100	94	90	86		92	88	85			89	86	83			87
4	97	89	84	79		95	88	83	79		86	82	78			84	80	77			82
5	92	83	78	73		90	83	77	73		81	76	72			79	75	72			77
6	87	78	72	68		86	77	72	68		76	71	67			74	70	67			73
7	83	73	67	63		81	73	67	63		71	66	63			70	66	62			69
8	79	69	63	59		78	69	63	59		67	62	59			66	62	58			65
9	75	65	59	55		74	65	59	55		64	59	55			63	58	55			62
10	71	62	56	52		70	61	56	52		60	55	52			60	55	52			59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	304686
5°	302701
10°	281933
15°	247223
20°	213563
25°	181683
30°	144065
35°	99443
40°	62447
45°	37250
50°	21573
55°	10873
60°	697
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL558030D010 2LBDLC*MB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	72.3	11.3
10°-20°	171.8	26.8
20°-30°	193.4	30.2
30°-40°	132.9	20.8
40°-50°	55.2	8.6
50°-60°	14.3	2.2
60°-70°	0.1	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	437.6	68.4
0°-40°	570.5	89.1
0°-60°	639.9	100.0
0°-90°	640.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	640.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	787	
5°	778	72
15°	616	172
25°	425	193
35°	210	133
45°	68	55
55°	16	14
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL558030D010 2LBDLC*MB

CANDELA DISTRIBUTION (FULL):

	0°
0°	786.6
2.5°	785.7
5°	778.5
7.5°	755.3
10°	716.8
12.5°	668.5
15°	616.5
17.5°	563.8
20°	518.1
22.5°	473.4
25°	425.1
27.5°	375.8
30°	322.1
32.5°	264.9
35°	210.3
37.5°	163.8
40°	123.5
42.5°	93.1
45°	68.0
47.5°	49.2
50°	35.8
52.5°	25.1
55°	16.1
57.5°	5.4
60°	0.9
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)