

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P#

Luminaire Tested: **LSSQWM2B05WFL559730D010 2LBD*GPH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P#
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14806)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQWM2B05WFL559730D010 2LBD*GPH
Description: 500 Lumen, 2inch Portfolio LED Cylinder
WIDE FLOOD OPTIC
SPUN ROUND TRIM WITH GRAPHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 525.0 lumens
Efficiency: N/A
Efficacy: 71.9 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.83
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 7.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL559730D010 2LBD*GPH

Luminous Intensity Polar Plot





TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL559730D010 2LBD*GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			0
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			100
1	113	111	108	106		111	108	106	104		104	103	101			101	99	98			93
2	108	103	99	95		105	101	97	94		98	95	92			95	92	90			86
3	102	95	90	86		100	94	89	86		91	88	84			89	86	83			80
4	97	89	83	79		95	88	83	79		86	81	78			84	80	77			74
5	92	83	77	73		90	82	77	72		80	75	72			79	74	71			69
6	87	78	72	67		85	77	71	67		75	70	67			74	70	66			64
7	83	73	67	63		81	72	67	62		71	66	62			70	65	62			60
8	78	69	63	58		77	68	62	58		67	62	58			66	61	58			56
9	75	65	59	55		73	64	59	55		63	58	54			62	58	54			53
10	71	61	55	51		70	61	55	51		60	55	51			59	54	51			50

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	250148
5°	247410
10°	228677
15°	200264
20°	172631
25°	147406
30°	116603
35°	80670
40°	52182
45°	31662
50°	18560
55°	10400
60°	3951
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL559730D010 2LBD*GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	59.0	11.2
10°-20°	139.2	26.5
20°-30°	156.7	29.8
30°-40°	108.1	20.6
40°-50°	46.7	8.9
50°-60°	14.5	2.8
60°-70°	1.0	0.2
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	354.8	67.6
0°-40°	462.9	88.2
0°-60°	524.1	99.8
0°-90°	525.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	525.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	646	
5°	636	59
15°	499	139
25°	345	157
35°	171	108
45°	58	47
55°	15	15
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P#

CATALOG NUMBER: LSSQWM2B05WFL559730D010 2LBD*GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	645.8
2.5°	644.3
5°	636.3
7.5°	615.0
10°	581.4
12.5°	541.8
15°	499.4
17.5°	456.9
20°	418.8
22.5°	382.2
25°	344.9
27.5°	305.3
30°	260.7
32.5°	213.8
35°	170.6
37.5°	134.0
40°	103.2
42.5°	77.6
45°	57.8
47.5°	42.5
50°	30.8
52.5°	22.0
55°	15.4
57.5°	10.3
60°	5.1
62.5°	1.5
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)