

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P#

Luminaire Tested: **LSRWM2B05WFL558035D010 2LBD*GPH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P#
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14806)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSRWM2B05WFL558035D010 2LBD*GPH
Description: 500 Lumen, 2inch Portfolio LED Cylinder
WIDE FLOOD OPTIC
SPUN ROUND TRIM WITH GRAPHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 717.0 lumens
Efficiency: N/A
Efficacy: 98.2 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.83
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 7.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P#

CATALOG NUMBER: LSRWM2B05WFL558035D010 2LBD*GPH

Luminous Intensity Polar Plot





TEST NUMBER: P#

CATALOG NUMBER: LSRWM2B05WFL558035D010 2LBD*GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			0
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			100
1	113	111	108	106		111	108	106	104		104	103	101			101	99	98			93
2	108	103	99	95		105	101	97	94		98	95	92			95	92	90			86
3	102	95	90	86		100	94	89	86		91	88	84			89	86	83			80
4	97	89	83	79		95	88	83	79		86	81	78			84	80	77			74
5	92	83	77	73		90	82	77	72		80	75	72			79	74	71			69
6	87	78	72	67		85	77	71	67		75	70	67			74	70	66			64
7	83	73	67	63		81	72	67	62		71	66	62			70	65	62			60
8	78	69	63	58		77	68	62	58		67	62	58			66	61	58			56
9	75	65	59	55		74	64	59	55		63	58	54			62	58	54			53
10	71	61	55	51		70	61	55	51		60	55	51			59	54	51			50

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	341639
5°	337889
10°	312297
15°	273489
20°	235781
25°	201300
30°	159228
35°	110177
40°	71296
45°	43275
50°	25309
55°	14182
60°	5423
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P#

CATALOG NUMBER: LSRWM2B05WFL558035D010 2LBD*GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	80.5	11.2
10°-20°	190.1	26.5
20°-30°	214.0	29.8
30°-40°	147.6	20.6
40°-50°	63.7	8.9
50°-60°	19.8	2.8
60°-70°	1.3	0.2
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	484.6	67.6
0°-40°	632.2	88.2
0°-60°	715.7	99.8
0°-90°	717.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	717.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	882	
5°	869	81
15°	682	190
25°	471	214
35°	233	148
45°	79	64
55°	21	20
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P#

CATALOG NUMBER: LSRWM2B05WFL558035D010 2LBD*GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	882
2.5°	880
5°	869
7.5°	840
10°	794
12.5°	740
15°	682
17.5°	624
20°	572
22.5°	522
25°	471
27.5°	417
30°	356
32.5°	292
35°	233
37.5°	183
40°	141
42.5°	106
45°	79
47.5°	58
50°	42
52.5°	30
55°	21
57.5°	14
60°	7
62.5°	2
65°	0
67.5°	0
70°	0
72.5°	0
75°	0
77.5°	0
80°	0
82.5°	0
85°	0
87.5°	0
90°	0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)