

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P224489

Luminaire Tested: **LSR2B05FL408050D010 2LBDL*WMH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P224489
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14831)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR2B05FL408050D010 2LBDL*WMH
Description: 500 Lumen, 2inch Portfolio LED Cylinder
FLOOD OPTIC
LENSED SPUN ROUND TRIM WITH WHEAT METALLIC HAZE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 770.4 lumens
Efficiency: N/A
Efficacy: 105.5 lumens/watt
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.59
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 7.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P224489

CATALOG NUMBER: LSR2B05FL408050D010 2LBDL*WMH

Luminous Intensity Polar Plot





TEST NUMBER: P224489

CATALOG NUMBER: LSR2B05FL408050D010 2LBDL*WMH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	114	112	110	108		112	110	108	106		106	104	103		102	101	100		99	98	97
2	110	106	102	100		108	104	101	98		101	98	96		98	96	94		95	94	92
3	106	100	96	93		104	99	95	92		96	93	91		94	91	89		92	90	88
4	102	95	91	87		100	94	90	87		92	89	86		90	87	85		88	86	84
5	98	91	86	82		96	90	85	82		88	84	81		87	83	81		85	82	80
6	94	87	82	78		93	86	81	78		85	81	77		83	80	77		82	79	77
7	91	83	78	75		89	82	78	74		81	77	74		80	76	74		79	76	73
8	87	79	75	71		86	79	74	71		78	74	71		77	73	71		76	73	70
9	84	76	71	68		83	76	71	68		75	71	68		74	70	68		73	70	67
10	81	73	69	65		80	73	68	65		72	68	65		72	68	65		71	67	65

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	699043
5°	684644
10°	606502
15°	476600
20°	320448
25°	186171
30°	93032
35°	43882
40°	20731
45°	9093
50°	4700
55°	2634
60°	1549
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P224489

CATALOG NUMBER: LSR2B05FL408050D010 2LBDL*WMH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	161.1	20.9
10°-20°	322.3	41.8
20°-30°	203.8	26.5
30°-40°	63.7	8.3
40°-50°	14.8	1.9
50°-60°	3.9	0.5
60°-70°	0.7	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	687.2	89.2
0°-40°	751.0	97.5
0°-60°	769.7	99.9
0°-90°	770.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	770.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1805	
5°	1761	161
15°	1188	322
25°	436	204
35°	93	64
45°	17	15
55°	4	4
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P224489

CATALOG NUMBER: LSR2B05FL408050D010 2LBDL*WMH

CANDELA DISTRIBUTION (FULL):

	0°
0°	1804.7
2.5°	1795.9
5°	1760.8
7.5°	1677.8
10°	1542.0
12.5°	1380.9
15°	1188.5
17.5°	978.5
20°	777.4
22.5°	591.8
25°	435.6
27.5°	307.6
30°	208.0
32.5°	138.7
35°	92.8
37.5°	62.5
40°	41.0
42.5°	25.4
45°	16.6
47.5°	11.7
50°	7.8
52.5°	5.9
55°	3.9
57.5°	2.9
60°	2.0
62.5°	2.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)