

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P265043

Luminaire Tested: **LD2B20D010 EU2B2010SP159035 2LBDL*LI**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P265043
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1711-432-2)
Test Lab: INNOVATION CENTER(G3)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD2B20D010 EU2B2010SP159035 2LBDL*LI
Description: 2000 Lumen, 2inch Portfolio LED Downlight
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1466.0 lumens
Efficiency: N/A
Efficacy: 70.1 lumens/watt
Spacing Criteria (0/90/45): 0.31 / 0.31 / 0.32
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P265043

CATALOG NUMBER: LD2B20D010 EU2B2010SP159035 2LBDL*LI

Luminous Intensity Polar Plot





TEST NUMBER: P265043

CATALOG NUMBER: LD2B20D010 EU2B2010SP159035 2LBDL*LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			50
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			102
1	115	113	111	110		113	111	110	108		107	106	105			104	103	102			100
2	112	108	106	103		110	107	104	102		104	102	100			101	99	98			98
3	109	104	101	98		107	103	100	97		100	98	96			98	96	94			96
4	105	100	97	94		104	99	96	93		97	95	92			96	93	91			94
5	103	97	93	91		101	96	93	90		95	92	89			93	91	89			92
6	100	94	90	88		99	94	90	87		92	89	87			91	88	86			90
7	98	92	88	85		97	91	88	85		90	87	85			89	86	84			88
8	95	89	86	83		94	89	85	83		88	85	82			87	84	82			86
9	93	87	83	81		92	87	83	81		86	83	81			85	82	80			85
10	91	85	82	79		91	85	81	79		84	81	79			84	81	79			83

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	5175266
5°	4212169
10°	2275318
15°	907222
20°	363790
25°	174197
30°	90295
35°	47761
40°	26470
45°	16396
50°	11283
55°	7569
60°	5822
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P265043

CATALOG NUMBER: LD2B20D010 EU2B2010SP159035 2LBDL*LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	684.0	46.7
10°-20°	539.7	36.8
20°-30°	159.2	10.9
30°-40°	53.0	3.6
40°-50°	19.9	1.4
50°-60°	8.8	0.6
60°-70°	1.4	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1382.9	94.3
0°-40°	1435.9	97.9
0°-60°	1464.6	99.9
0°-90°	1466.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1466.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	10490	
5°	8505	684
15°	1776	540
25°	320	159
35°	79	53
45°	24	20
55°	9	9
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P265043

CATALOG NUMBER: LD2B20D010 EU2B2010SP159035 2LBDL*LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	10489.8
2.5°	10067.1
5°	8505.2
7.5°	6552.8
10°	4541.8
12.5°	2906.5
15°	1776.2
17.5°	1083.3
20°	692.9
22.5°	463.9
25°	320.0
27.5°	226.1
30°	158.5
32.5°	111.6
35°	79.3
37.5°	55.8
40°	41.1
42.5°	32.3
45°	23.5
47.5°	20.6
50°	14.7
52.5°	11.7
55°	8.8
57.5°	8.8
60°	5.9
62.5°	2.9
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)