

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P1307962

Luminaire Tested: LDSQA3D09R309027DE010 3LSQPHR1MMS

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1307962
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2510-583-4)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LDSQA3D09R309027DE010 3LSQPHR1MMS
Description: 3in Adjustable LED luminaire with, R30 optic, 2700K CCT AND, 90CRI , 3LSQPHR1MMS TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 792.0 lumens
Efficiency: N/A
Efficacy: 71.4 lumens/watt
Spacing Criteria (0/90/45): 0.5 / 0.49 / 0.46
Luminous Opening: Rectangular (W 0.25' x L: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1307962
CATALOG NUMBER: LDSQA3D09R309027DE010 3LSQPHR1MMS

Luminous Intensity Polar Plot





TEST NUMBER: P1307962
 CATALOG NUMBER: LDSQA3D09R309027DE010 3LSQPHR1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	102	102	102	100
1	115	113	111	110	113	111	109	108	107	106	105	103	103	102	100	99	99	99	99	99	97
2	112	108	105	103	110	107	104	102	104	101	100	101	99	98	98	97	96	96	96	96	94
3	108	104	101	98	107	103	100	97	100	98	96	98	96	94	96	94	93	96	94	93	92
4	105	100	97	94	104	99	96	93	97	94	92	95	93	91	94	92	90	94	92	90	89
5	102	97	93	90	101	96	93	90	95	91	89	93	90	88	92	89	88	92	89	88	87
6	100	94	90	87	99	93	90	87	92	89	86	91	88	86	90	87	85	90	87	85	84
7	97	91	87	84	96	91	87	84	90	86	84	88	86	83	88	85	83	88	85	83	82
8	95	89	85	82	94	88	84	82	87	84	82	86	83	81	86	83	81	86	83	81	80
9	92	86	82	80	92	86	82	80	85	82	79	84	81	79	84	81	79	84	81	79	78
10	90	84	80	78	90	84	80	78	83	80	77	82	79	77	82	79	77	82	79	77	76

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	562927	562927	562927
5°	548429	544660	540165
10°	462836	448618	441343
15°	278912	271120	276112
20°	94607	109251	126020
25°	17387	27250	32172
30°	5966	6662	7477
35°	1724	2144	2292
40°	450	764	607
45°	170	170	170
50°	188	0	188
55°	0	0	0
60°	0	0	0
65°	0	0	0
70°	0	0	0
75°	0	0	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 52.5°
 Luminance: 198 cd/sqm



TEST NUMBER: P1307962

CATALOG NUMBER: LDSQA3D09R309027DE010 3LSQPHR1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	282.6	35.7
10°-20°	413.1	52.2
20°-30°	87.4	11.0
30°-40°	8.0	1.0
40°-50°	0.8	0.1
50°-60°	0.1	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	783.1	98.9
0°-40°	791.2	99.9
0°-60°	792.0	100.0
0°-90°	792.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	792.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3269	3269	3269	3269	3269	
5°	3172	3166	3150	3141	3124	286
15°	1564	1559	1521	1556	1549	413
25°	92	102	143	169	169	67
35°	8	10	10	12	11	7
45°	1	1	1	1	1	1
55°	0	0	0	0	0	0
65°	0	0	0	0	0	0
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	0



TEST NUMBER: P1307962

CATALOG NUMBER: LDSQA3D09R309027DE010 3LSQPHR1MMS

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3268.6	3268.6	3268.6	3268.6	3268.6
1°	3269.3	3265.9	3261.1	3267.9	3263.2
2°	3262.5	3254.3	3247.4	3254.3	3252.2
3°	3242.0	3235.2	3230.4	3233.8	3233.8
4°	3211.3	3203.7	3199.7	3200.3	3190.1
5°	3172.3	3166.2	3150.5	3140.9	3124.5
6°	3115.0	3100.0	3080.8	3065.1	3044.0
7°	3037.1	3013.9	2986.6	2959.3	2932.7
8°	2912.2	2901.3	2864.4	2846.0	2819.3
9°	2794.7	2768.1	2728.5	2698.5	2684.1
10°	2646.6	2607.0	2565.3	2541.4	2523.7
11°	2471.1	2430.8	2397.3	2362.5	2335.2
12°	2264.9	2230.7	2192.5	2169.3	2137.2
13°	2020.4	2015.7	1972.6	1965.1	1961.0
14°	1810.8	1791.7	1749.4	1761.0	1763.7
15°	1564.3	1558.9	1520.6	1556.1	1548.6
17.5°	979.8	981.9	1005.8	1061.8	1079.5
20°	516.2	531.9	596.1	663.7	687.6
22.5°	208.9	243.8	309.3	355.1	385.8
25°	91.5	102.4	143.4	168.7	169.3
27.5°	51.9	52.6	69.0	71.7	73.1
30°	30.0	30.7	33.5	35.5	37.6
32.5°	16.4	17.8	18.4	21.2	21.2
35°	8.2	10.2	10.2	12.3	10.9
37.5°	4.8	5.5	6.1	6.1	5.5
40°	2.0	2.7	3.4	3.4	2.7
42.5°	0.7	1.4	1.4	1.4	2.0
45°	0.7	0.7	0.7	0.7	0.7
47.5°	0.7	0.7	0.0	0.7	0.7
50°	0.7	0.0	0.0	0.0	0.7
52.5°	0.7	0.0	0.0	0.0	0.7
55°	0.0	0.0	0.0	0.0	0.0
57.5°	0.0	0.0	0.0	0.0	0.0
60°	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P1307962
CATALOG NUMBER: LDSQA3D09R309027DE010 3LSQPHR1MMS

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)