

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P1314586

Luminaire Tested: LDSQA3D13R129730DE010 3LSQCDR1MMS

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1314586
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LDSQA3D13R129730DE010 3LSQCDR1MMS
Description: 3in Adjustable LED luminaire with, R12 optic, 3000K CCT AND, 97CRI , 3LSQCDR1MMS TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 994.0 lumens
Efficiency: N/A
Efficacy: 64.1 lumens/watt
Spacing Criteria (0/90/45): 0.22 / 0.22 / 0.22
Luminous Opening: Rectangular (W 0.25' x L: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 15.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1314586
CATALOG NUMBER: LDSQA3D13R129730DE010 3LSQCDR1MMS

Luminous Intensity Polar Plot





TEST NUMBER: P1314586
 CATALOG NUMBER: LDSQA3D13R129730DE010 3LSQCDR1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20		
RC	80				70				50				30				10		0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10		0
RCR																			
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102		100
1	116	114	113	111	114	112	111	109	108	107	106	104	104	103	101	101	100		98
2	113	110	108	106	111	108	106	104	105	104	102	103	101	100	100	99	98		97
3	110	107	104	102	109	105	103	101	103	101	99	101	99	98	99	98	96		95
4	108	104	101	98	107	103	100	98	101	99	97	99	97	96	98	96	95		94
5	106	102	98	96	105	101	98	96	99	97	95	98	96	94	97	95	93		92
6	104	99	96	94	103	99	96	94	98	95	93	96	94	93	95	93	92		91
7	102	98	94	92	101	97	94	92	96	93	92	95	93	91	94	92	91		90
8	101	96	93	91	100	95	93	90	95	92	90	94	92	90	93	91	90		89
9	99	94	91	89	98	94	91	89	93	91	89	93	90	89	92	90	88		88
10	98	93	90	88	97	93	90	88	92	90	88	91	89	88	91	89	87		87

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2522028
5°	1629554
10°	459776
15°	129997
20°	54360
25°	24076
30°	12290
35°	6497
40°	2788
45°	755
50°	831
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 50°
 Luminance: 831 cd/sqm



TEST NUMBER: P1314586

CATALOG NUMBER: LDSQA3D13R129730DE010 3LSQCDR1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	664.1	66.8
10°-20°	240.9	24.2
20°-30°	64.5	6.5
30°-40°	20.3	2.0
40°-50°	3.8	0.4
50°-60°	0.3	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	969.6	97.5
0°-40°	989.9	99.6
0°-60°	994.0	100.0
0°-90°	994.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	994.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14644	
5°	9426	664
15°	729	241
25°	127	65
35°	31	20
45°	3	4
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P1314586
CATALOG NUMBER: LDSQA3D13R129730DE010 3LSQCDR1MMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	14644.0
1°	14396.8
2°	13701.7
3°	12512.3
4°	11035.5
5°	9425.9
6°	7748.3
7°	6246.9
8°	4807.2
9°	3577.6
10°	2629.1
11°	1937.1
12°	1458.2
13°	1130.7
14°	895.9
15°	729.1
17.5°	463.4
20°	296.6
22.5°	191.5
25°	126.7
27.5°	86.5
30°	61.8
32.5°	43.3
35°	30.9
37.5°	21.6
40°	12.4
42.5°	6.2
45°	3.1
47.5°	3.1
50°	3.1
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0



TEST NUMBER: P1314586
CATALOG NUMBER: LDSQA3D13R129730DE010 3LSQCDR1MMS

CANDELA DISTRIBUTION (continued):



(END OF REPORT)