

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P1316218

Luminaire Tested: LDSQA3D05R159740DE010 3LSQCDR1MB

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1316218
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2510-583-21)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LDSQA3D05R159740DE010 3LSQCDR1MB
Description: 3in Adjustable LED luminaire with, R15 optic, 4000K CCT AND, 97CRI , 3LSQCDR1MB TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 613.0 lumens
Efficiency: N/A
Efficacy: 85.1 lumens/watt
Spacing Criteria (0/90/45): 0.29 / 0.29 / 0.29
Luminous Opening: Rectangular (W 0.25' x L: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1316218

CATALOG NUMBER: LDSQA3D05R159740DE010 3LSQCDR1MB

Luminous Intensity Polar Plot



TEST NUMBER: P1316218

CATALOG NUMBER: LDSQA3D05R159740DE010 3LSQCDR1MB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	116	114	112	111	113	112	110	109	108	107	106		104	103	102		101
2	113	109	107	105	111	108	106	104	105	103	101		102	101	99		99
3	110	106	103	100	108	105	102	100	102	100	98		100	98	97		98
4	107	103	99	97	106	102	99	96	100	97	95		98	96	94		96
5	105	100	97	94	104	99	96	94	98	95	93		96	94	92		95
6	103	97	94	92	102	97	94	91	96	93	91		94	92	90		93
7	101	95	92	90	100	95	92	89	94	91	89		93	90	88		92
8	99	93	90	88	98	93	90	88	92	89	87		91	89	87		90
9	97	91	88	86	96	91	88	86	90	88	86		90	87	85		89
10	95	90	87	84	95	90	86	84	89	86	84		88	86	84		88

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	945933	945933	945933
5°	770165	772672	771168
10°	359255	362490	357908
15°	112809	113772	113077
20°	44701	46479	43271
25°	18053	21834	17406
30°	7239	9923	6841
35°	2144	4373	2039
40°	652	1641	540
45°	122	365	122
50°	0	134	0
55°	0	0	0
60°	0	0	0
65°	0	0	0
70°	0	0	0
75°	0	0	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 45°

Vertical Angle: 45°

Luminance: 365 cd/sqm

TEST NUMBER: P1316218

CATALOG NUMBER: LDSQA3D05R159740DE010 3LSQCDR1MB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	343.9	56.1
10°-20°	205.7	33.6
20°-30°	51.9	8.5
30°-40°	10.6	1.7
40°-50°	1.0	0.2
50°-60°	0.0	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	601.4	98.1
0°-40°	612.0	99.8
0°-60°	613.0	100.0
0°-90°	613.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	613.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	5492	5492	5492	5492	5492	
5°	4455	4447	4469	4458	4461	343
15°	633	638	638	629	634	206
25°	95	104	115	102	92	49
35°	10	14	21	13	10	8
45°	0	1	2	1	0	1
55°	0	0	0	0	0	0
65°	0	0	0	0	0	0
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	

TEST NUMBER: P1316218

CATALOG NUMBER: LDSQA3D05R159740DE010 3LSQCDR1MB

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	5492.5	5492.5	5492.5	5492.5	5492.5
1°	5443.0	5461.4	5451.7	5459.5	5450.8
2°	5325.2	5349.9	5342.2	5339.7	5346.5
3°	5117.7	5146.3	5145.3	5138.0	5126.4
4°	4834.5	4822.9	4840.8	4838.9	4819.0
5°	4454.9	4446.6	4469.4	4458.3	4460.7
6°	3990.4	4026.3	4018.5	4019.5	4028.7
7°	3491.5	3510.8	3527.3	3540.9	3522.0
8°	3033.3	3028.4	3029.9	3045.4	2993.0
9°	2520.3	2550.3	2531.0	2499.9	2519.8
10°	2054.3	2072.8	2072.8	2045.6	2046.6
11°	1637.8	1652.9	1642.2	1649.0	1606.3
12°	1320.3	1282.9	1274.2	1281.0	1280.5
13°	1008.0	1010.4	1008.0	1007.5	1002.7
14°	790.3	802.9	797.6	784.5	778.7
15°	632.7	638.1	638.1	628.9	634.2
17.5°	380.1	386.4	387.9	381.6	381.6
20°	243.9	246.8	253.6	244.4	236.1
22.5°	150.3	156.6	168.2	154.7	147.9
25°	95.0	103.8	114.9	101.8	91.6
27.5°	59.6	66.9	76.6	64.0	57.7
30°	36.4	41.2	49.9	40.2	34.4
32.5°	20.4	24.2	31.5	23.3	19.4
35°	10.2	13.6	20.8	13.1	9.7
37.5°	5.8	7.3	13.1	6.3	5.3
40°	2.9	3.9	7.3	3.9	2.4
42.5°	1.0	1.9	2.9	1.9	1.0
45°	0.5	1.0	1.5	1.0	0.5
47.5°	0.0	0.0	0.5	0.0	0.0
50°	0.0	0.0	0.5	0.0	0.0
52.5°	0.0	0.0	0.0	0.0	0.0
55°	0.0	0.0	0.0	0.0	0.0
57.5°	0.0	0.0	0.0	0.0	0.0
60°	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P1316218

CATALOG NUMBER: LDSQA3D05R159740DE010 3LSQCDR1MB

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)