

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P1325279

Luminaire Tested: LDSQA3D05R50W2N902750DE010 3LSQCDR1MMS_5000K

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1325279
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2510-583-27)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LDSQA3D05R50W2N902750DE010 3LSQCDR1MMS_5000K
Description: 3in Adjustable Tunable White LED luminaire with, R50 optic, 5000K CCT AND, 90CRI ,
3LSQCDR1MMS TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 558.0 lumens
Efficiency: N/A
Efficacy: 94.6 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.78
Luminous Opening: Rectangular (W 0.25' x L: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 5.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1325279
CATALOG NUMBER: LDSQA3D05R50W2N902750DE010 3LSQCDR1MMS_5000K

Luminous Intensity Polar Plot





TEST NUMBER: P1325279

CATALOG NUMBER: LDSQA3D05R50W2N902750DE010 3LSQCDR1MMS_5000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	102	102	102	100
1	114	112	109	107	112	110	108	106	106	104	102	102	101	99	98	97	97	97	97	97	95
2	109	105	101	98	107	103	100	97	100	98	95	97	95	93	95	93	91	91	91	91	90
3	105	99	95	91	103	98	94	90	95	92	89	93	90	88	91	88	86	86	86	86	85
4	100	94	89	85	99	93	88	85	90	87	84	89	85	83	87	84	82	82	82	82	80
5	96	89	84	80	95	88	83	79	86	82	79	85	81	78	83	80	77	77	77	77	76
6	92	84	79	75	91	83	79	75	82	78	74	81	77	74	79	76	73	73	73	73	72
7	88	80	75	71	87	79	74	71	78	74	70	77	73	70	76	72	70	70	70	70	69
8	85	76	71	67	83	76	71	67	75	70	67	74	70	67	73	69	66	66	66	66	65
9	81	73	67	64	80	72	67	64	71	67	64	70	66	63	70	66	63	63	63	63	62
10	78	69	64	61	77	69	64	61	68	64	60	67	63	60	67	63	60	60	60	60	59

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	149231	149231	149231
5°	146637	146222	145807
10°	141425	139886	140166
15°	130086	128446	128802
20°	116160	115060	115720
25°	90415	94196	89427
30°	48981	54688	48106
35°	15432	18375	15096
40°	3417	4766	3237
45°	97	1461	97
50°	0	214	0
55°	0	0	0
60°	0	0	0
65°	0	0	0
70°	0	0	0
75°	0	0	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 45°
 Vertical Angle: 45°
 Luminance: 1461 cd/sqm



TEST NUMBER: P1325279

CATALOG NUMBER: LDSQA3D05R50W2N902750DE010 3LSQCDR1MMS_5000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	79.4	14.2
10°-20°	201.7	36.1
20°-30°	212.4	38.1
30°-40°	60.7	10.9
40°-50°	3.8	0.7
50°-60°	0.0	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	493.5	88.4
0°-40°	554.2	99.3
0°-60°	558.0	100.0
0°-90°	558.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	558.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	866	866	866	866	866	
5°	848	847	846	845	843	80
15°	730	725	720	722	722	203
25°	476	493	496	490	471	208
35°	73	79	87	74	72	57
45°	0	2	6	2	0	2
55°	0	0	0	0	0	0
65°	0	0	0	0	0	0
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	0



TEST NUMBER: P1325279

CATALOG NUMBER: LDSQA3D05R50W2N902750DE010 3LSQCDR1MMS_5000K

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	866.5	866.5	866.5	866.5	866.5
1°	866.9	867.3	866.5	867.3	865.3
2°	865.7	864.9	864.1	864.5	863.3
3°	861.3	860.9	859.3	859.7	858.1
4°	855.7	854.6	853.4	852.6	851.0
5°	848.2	847.4	845.8	845.0	843.4
6°	841.8	840.2	837.4	836.6	835.0
7°	833.4	832.6	829.0	828.2	827.4
8°	827.0	824.6	820.2	820.6	818.6
9°	818.6	815.4	811.0	811.0	811.4
10°	808.7	803.9	799.9	801.1	801.5
11°	795.5	792.3	786.3	789.1	789.1
12°	781.1	777.1	772.7	775.1	776.7
13°	764.3	761.2	757.2	759.6	758.8
14°	748.0	742.0	739.2	742.4	741.2
15°	729.6	724.8	720.4	721.6	722.4
17.5°	680.5	675.3	672.1	672.5	676.1
20°	633.8	631.8	627.8	629.4	631.4
22.5°	578.7	579.5	574.8	576.0	580.7
25°	475.8	493.3	495.7	490.1	470.6
27.5°	352.4	378.8	386.8	374.0	350.0
30°	246.3	253.5	275.0	250.7	241.9
32.5°	144.5	155.3	166.8	150.1	144.1
35°	73.4	78.6	87.4	74.2	71.8
37.5°	33.9	36.3	39.9	33.9	31.9
40°	15.2	18.0	21.2	17.2	14.4
42.5°	4.8	8.4	11.2	7.6	4.4
45°	0.4	2.0	6.0	2.0	0.4
47.5°	0.0	0.4	2.4	0.4	0.0
50°	0.0	0.0	0.8	0.0	0.0
52.5°	0.0	0.0	0.0	0.0	0.0
55°	0.0	0.0	0.0	0.0	0.0
57.5°	0.0	0.0	0.0	0.0	0.0
60°	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P1325279
CATALOG NUMBER: LDSQA3D05R50W2N902750DE010 3LSQCDR1MMS_5000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)