

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P749487

Luminaire Tested: LD4D50D010-EU4DR5540509024-4LBSQW1MW

Issue Date: 1/30/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P749487  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-52)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 1/30/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD4D50D010-EU4DR5540509024-4LBSQW1MW  
Description: 4 INCH SQAURE DEEP 45° CUTOFF MATTE WHITE TRIM, WITH 55° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 2400K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3863.9 lumens  
Efficiency: N/A  
Efficacy: 82.2 lumens/watt  
Spacing Criteria (0/90/45): 0.89 / 0.89 / 0.87  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct


Input Watts (W): 47  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



TEST NUMBER: P749487

CATALOG NUMBER: LD4D50D010-EU4DR5540509024-4LBSQW1MW

### Luminous Intensity Polar Plot





TEST NUMBER: P749487

CATALOG NUMBER: LD4D50D010-EU4DR5540509024-4LBSQW1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |  |     |     |     |     |  |     |     |     |  |     |     |     |  |     |     |     |
|-----|-----|-----|-----|-----|--|-----|-----|-----|-----|--|-----|-----|-----|--|-----|-----|-----|--|-----|-----|-----|
| RF  | 20  |     |     |     |  | 20  |     |     |     |  | 20  |     |     |  |     | 20  |     |  |     |     | 20  |
| RC  | 80  |     |     |     |  | 70  |     |     |     |  | 50  |     |     |  |     | 30  |     |  |     |     | 10  |
| RW  | 70  | 50  | 30  | 10  |  | 70  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  | 30  | 10  |
| RCR |     |     |     |     |  |     |     |     |     |  |     |     |     |  |     |     |     |  |     |     |     |
| 0   | 119 | 119 | 119 | 119 |  | 116 | 116 | 116 | 116 |  | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 | 102 | 102 |
| 1   | 114 | 111 | 108 | 106 |  | 111 | 109 | 106 | 104 |  | 105 | 103 | 101 |  | 101 | 99  | 98  |  | 97  | 96  | 95  |
| 2   | 108 | 103 | 99  | 96  |  | 106 | 101 | 98  | 95  |  | 98  | 95  | 92  |  | 95  | 93  | 90  |  | 92  | 90  | 89  |
| 3   | 102 | 96  | 91  | 87  |  | 100 | 95  | 90  | 86  |  | 92  | 88  | 85  |  | 90  | 86  | 84  |  | 87  | 85  | 82  |
| 4   | 97  | 90  | 84  | 80  |  | 95  | 88  | 83  | 79  |  | 86  | 82  | 78  |  | 84  | 81  | 78  |  | 82  | 79  | 77  |
| 5   | 92  | 84  | 78  | 74  |  | 91  | 83  | 77  | 73  |  | 81  | 76  | 73  |  | 79  | 75  | 72  |  | 78  | 74  | 71  |
| 6   | 88  | 79  | 73  | 68  |  | 86  | 78  | 72  | 68  |  | 76  | 71  | 68  |  | 75  | 70  | 67  |  | 74  | 70  | 67  |
| 7   | 83  | 74  | 68  | 64  |  | 82  | 73  | 67  | 63  |  | 72  | 67  | 63  |  | 71  | 66  | 63  |  | 70  | 65  | 62  |
| 8   | 79  | 69  | 63  | 59  |  | 78  | 69  | 63  | 59  |  | 68  | 63  | 59  |  | 67  | 62  | 59  |  | 66  | 62  | 58  |
| 9   | 75  | 66  | 60  | 56  |  | 74  | 65  | 59  | 55  |  | 64  | 59  | 55  |  | 63  | 58  | 55  |  | 62  | 58  | 55  |
| 10  | 72  | 62  | 56  | 52  |  | 71  | 61  | 56  | 52  |  | 61  | 56  | 52  |  | 60  | 55  | 52  |  | 59  | 55  | 52  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 473405 |
| 5°  | 454605 |
| 10° | 452883 |
| 15° | 439882 |
| 20° | 394409 |
| 25° | 325959 |
| 30° | 246221 |
| 35° | 178533 |
| 40° | 114261 |
| 45° | 52181  |
| 50° | 17066  |
| 55° | 7372   |
| 60° | 3169   |
| 65° | 414    |
| 70° | 0      |
| 75° | 0      |
| 80° | 0      |
| 85° | 0      |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 52181 cd/sqm



TEST NUMBER: P749487

CATALOG NUMBER: LD4D50D010-EU4DR5540509024-4LBSQW1MW

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 394.4  | 10.2      |
| 10°-20°   | 1076.4 | 27.9      |
| 20°-30°   | 1226.7 | 31.7      |
| 30°-40°   | 835.1  | 21.6      |
| 40°-50°   | 287.8  | 7.4       |
| 50°-60°   | 39.8   | 1.0       |
| 60°-70°   | 3.8    | 0.1       |
| 70°-80°   | 0.0    | 0.0       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 2697.5 | 69.8      |
| 0°-40°    | 3532.5 | 91.4      |
| 0°-60°    | 3860.1 | 99.9      |
| 0°-90°    | 3863.9 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 3863.9 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 4333 |      |
| 5°  | 4145 | 394  |
| 15° | 3889 | 1076 |
| 25° | 2704 | 1227 |
| 35° | 1338 | 835  |
| 45° | 338  | 288  |
| 55° | 39   | 40   |
| 65° | 2    | 4    |
| 75° | 0    | 0    |
| 85° | 0    | 0    |
| 90° | 0    |      |



TEST NUMBER: P749487

CATALOG NUMBER: LD4D50D010-EU4DR5540509024-4LBSQW1MW

**CANDELA DISTRIBUTION (FULL):**

| 0°    |        |
|-------|--------|
| 0°    | 4332.8 |
| 2.5°  | 4233.4 |
| 5°    | 4144.9 |
| 7.5°  | 4101.4 |
| 10°   | 4082.0 |
| 12.5° | 4017.6 |
| 15°   | 3888.8 |
| 17.5° | 3684.2 |
| 20°   | 3392.1 |
| 22.5° | 3055.0 |
| 25°   | 2703.8 |
| 27.5° | 2338.2 |
| 30°   | 1951.6 |
| 32.5° | 1624.1 |
| 35°   | 1338.5 |
| 37.5° | 1066.8 |
| 40°   | 801.1  |
| 42.5° | 555.2  |
| 45°   | 337.7  |
| 47.5° | 182.0  |
| 50°   | 100.4  |
| 52.5° | 59.6   |
| 55°   | 38.7   |
| 57.5° | 24.7   |
| 60°   | 14.5   |
| 62.5° | 6.4    |
| 65°   | 1.6    |
| 67.5° | 0.5    |
| 70°   | 0.0    |
| 72.5° | 0.0    |
| 75°   | 0.0    |
| 77.5° | 0.0    |
| 80°   | 0.0    |
| 82.5° | 0.0    |
| 85°   | 0.0    |
| 87.5° | 0.0    |
| 90°   | 0.0    |



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report







— 0°-180°







(END OF REPORT)