

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P206112

Luminaire Tested: **LD4B15D010 EU4B10209027 4LBSMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P206112
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD4B15D010 EU4B10209027 4LBSMW1
Description: PORTFOLIO 4 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-14.39W DE010-14.29W D5LT-14.34W DMX-14.46W DL2-15.8W
DL3-15.28W DLE-15.432W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1258.0 lumens
Efficiency: N/A
Efficacy: 88.0 lumens/watt
Spacing Criteria (0/90/45): 1.24 / 1.24 / 1.34
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P206112

CATALOG NUMBER: LD4B15D010 EU4B10209027 4LBSMW1

Luminous Intensity Polar Plot






TEST NUMBER: P206112

CATALOG NUMBER: LD4B15D010 EU4B10209027 4LBSMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	99	107	104	100	97	99	97	94		96	93	91		92
2	101	93	87	82	98	92	86	81	88	83	79		85	81	77		82
3	93	83	75	69	90	81	74	69	78	72	67		76	70	66		73
4	85	74	66	59	83	72	65	59	70	63	58		68	62	57		66
5	78	66	58	51	76	65	57	51	63	56	51		61	55	50		59
6	73	60	51	45	71	59	51	45	57	50	44		55	49	44		54
7	67	54	46	40	66	54	46	40	52	45	40		51	44	39		49
8	63	50	41	36	61	49	41	36	48	41	35		46	40	35		45
9	59	46	38	32	57	45	37	32	44	37	32		43	36	32		42
10	55	42	34	29	54	42	34	29	41	34	29		40	33	29		39

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P206112

CATALOG NUMBER: LD4B15D010 EU4B10209027 4LBSMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	48.0	3.8
10°-20°	136.9	10.9
20°-30°	206.2	16.4
30°-40°	245.3	19.5
40°-50°	244.9	19.5
50°-60°	199.2	15.8
60°-70°	122.5	9.7
70°-80°	47.5	3.8
80°-90°	7.6	0.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	391.1	31.1
0°-40°	636.4	50.6
0°-60°	1080.5	85.9
0°-90°	1258.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1258.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	507	
5°	505	48
15°	486	137
25°	449	206
35°	393	245
45°	318	245
55°	223	199
65°	123	123
75°	43	47
85°	6	8
90°	0	



TEST NUMBER: P206112

CATALOG NUMBER: LD4B15D010 EU4B10209027 4LBSMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	506.9
2.5°	507.6
5°	505.4
7.5°	502.4
10°	498.7
12.5°	492.0
15°	486.0
17.5°	477.1
20°	467.4
22.5°	458.4
25°	448.7
27.5°	435.3
30°	421.9
32.5°	409.2
35°	392.8
37.5°	374.9
40°	358.5
42.5°	338.4
45°	318.3
47.5°	296.7
50°	273.6
52.5°	249.7
55°	222.9
57.5°	196.8
60°	171.4
62.5°	146.8
65°	123.0
67.5°	100.6
70°	79.8
72.5°	60.4
75°	43.2
77.5°	28.3
80°	17.1
82.5°	10.4
85°	6.0
87.5°	3.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)