

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P779057

Luminaire Tested: LER4D05D010-EC4DR550210IC9035-4LBS1H

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P779057
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-52)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4D05D010-EC4DR550210IC9035-4LBS1H
Description: 4 INCH ROUND SHALLOW SEMI-SPECULAR CLEAR TRIM, WITH 55° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 722.0 lumens
Efficiency: N/A
Efficacy: 96.3 lumens/watt
Spacing Criteria (0/90/45): 0.89 / 0.89 / 0.87
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 7.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P779057

CATALOG NUMBER: LER4D05D010-EC4DR550210IC9035-4LBS1H

Luminous Intensity Polar Plot





TEST NUMBER: P779057

CATALOG NUMBER: LER4D05D010-EC4DR550210IC9035-4LBS1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20							
RC	80				70				50				30				10				0			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																								
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100						
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94						
2	108	103	99	96	106	101	98	95	98	95	92	95	93	90	92	90	89	87						
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81						
4	97	90	84	80	95	88	83	79	86	82	78	84	81	78	82	79	77	75						
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70						
6	88	79	73	68	86	78	72	68	76	71	68	75	70	67	74	70	67	65						
7	83	74	68	64	82	73	67	63	72	67	63	71	66	63	70	65	62	61						
8	79	69	63	59	78	69	63	59	68	63	59	67	62	59	66	62	58	57						
9	75	66	60	56	74	65	59	55	64	59	55	63	58	55	62	58	55	54						
10	72	62	56	52	71	61	56	52	61	56	52	60	55	52	59	55	52	50						

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	88458
5°	84946
10°	84630
15°	82201
20°	73705
25°	60905
30°	46012
35°	33359
40°	21352
45°	9750
50°	3179
55°	1372
60°	590
65°	78
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 9750 cd/sqm



TEST NUMBER: P779057

CATALOG NUMBER: LER4D05D010-EC4DR550210IC9035-4LBS1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	73.7	10.2
10°-20°	201.1	27.9
20°-30°	229.2	31.7
30°-40°	156.0	21.6
40°-50°	53.8	7.4
50°-60°	7.4	1.0
60°-70°	0.7	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	504.1	69.8
0°-40°	660.1	91.4
0°-60°	721.3	99.9
0°-90°	722.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	722.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	810	
5°	774	74
15°	727	201
25°	505	229
35°	250	156
45°	63	54
55°	7	7
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P779057

CATALOG NUMBER: LER4D05D010-EC4DR550210IC9035-4LBS1H

CANDELA DISTRIBUTION (FULL):

	0°
0°	809.6
2.5°	791.1
5°	774.5
7.5°	766.4
10°	762.8
12.5°	750.7
15°	726.7
17.5°	688.5
20°	633.9
22.5°	570.8
25°	505.2
27.5°	436.9
30°	364.7
32.5°	303.5
35°	250.1
37.5°	199.3
40°	149.7
42.5°	103.8
45°	63.1
47.5°	34.0
50°	18.7
52.5°	11.1
55°	7.2
57.5°	4.6
60°	2.7
62.5°	1.2
65°	0.3
67.5°	0.1
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)