

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P779096

Luminaire Tested: LER4D05D010-EC4DR650210IC9027-4LBS1B

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P779096
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4D05D010-EC4DR650210IC9027-4LBS1B
Description: 4 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 526.9 lumens
Efficiency: N/A
Efficacy: 70.3 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct

Input Watts (W): 7.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P779096

CATALOG NUMBER: LER4D05D010-EC4DR650210IC9027-4LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P779096

CATALOG NUMBER: LER4D05D010-EC4DR650210IC9027-4LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	107	105	111	108	106	103	104	102	100		100	99	97		97
2	107	102	97	94	105	100	96	92	97	93	90		94	91	89		91
3	101	94	88	84	99	92	87	83	90	86	82		87	84	81		85
4	95	87	81	76	93	86	80	76	84	79	75		82	77	74		80
5	90	81	74	70	88	80	74	69	78	73	69		76	72	68		75
6	85	75	69	64	83	74	68	64	73	67	63		71	67	63		70
7	80	70	64	59	79	69	63	59	68	63	59		67	62	58		66
8	76	66	59	55	75	65	59	55	64	58	54		63	58	54		62
9	72	61	55	51	71	61	55	51	60	54	51		59	54	50		58
10	68	58	52	47	67	57	51	47	57	51	47		56	51	47		55

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	27946
5°	27877
10°	27850
15°	26991
20°	24575
25°	21414
30°	17811
35°	14117
40°	10186
45°	6434
50°	3353
55°	1782
60°	934
65°	511
70°	222
75°	226
80°	168
85°	134

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6434 cd/sqm



TEST NUMBER: P779096

CATALOG NUMBER: LER4D05D010-EC4DR650210IC9027-4LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	45.2	8.6
10°-20°	123.9	23.5
20°-30°	151.5	28.7
30°-40°	122.9	23.3
40°-50°	61.2	11.6
50°-60°	17.1	3.2
60°-70°	3.9	0.7
70°-80°	1.0	0.2
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	320.6	60.8
0°-40°	443.5	84.2
0°-60°	521.8	99.0
0°-90°	526.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	526.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	478	
5°	476	45
15°	446	124
25°	332	151
35°	198	123
45°	78	61
55°	18	17
65°	4	4
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P779096

CATALOG NUMBER: LER4D05D010-EC4DR650210IC9027-4LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	478.5
2.5°	478.1
5°	475.5
7.5°	473.9
10°	469.6
12.5°	460.9
15°	446.4
17.5°	423.8
20°	395.4
22.5°	364.7
25°	332.3
27.5°	297.6
30°	264.1
32.5°	231.0
35°	198.0
37.5°	165.0
40°	133.6
42.5°	104.2
45°	77.9
47.5°	54.3
50°	36.9
52.5°	25.4
55°	17.5
57.5°	11.8
60°	8.0
62.5°	5.6
65°	3.7
67.5°	1.9
70°	1.3
72.5°	1.2
75°	1.0
77.5°	0.7
80°	0.5
82.5°	0.3
85°	0.2
87.5°	0.1
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)