

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P780611

Luminaire Tested: LER4D25D010-EC4DR6020359027-4LBS1MW

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P780611
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-60)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4D25D010-EC4DR6020359027-4LBS1MW
Description: 4 INCH ROUND SHALLOW MATTE WHITE TRIM, WITH 60° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2315.1 lumens
Efficiency: N/A
Efficacy: 92.2 lumens/watt
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 25.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P780611

CATALOG NUMBER: LER4D25D010-EC4DR6020359027-4LBS1MW

Luminous Intensity Polar Plot





TEST NUMBER: P780611

CATALOG NUMBER: LER4D25D010-EC4DR6020359027-4LBS1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	108	106	111	109	106	104	105	103	101		101	99	98		97
2	108	103	99	96	106	101	98	95	98	95	92		95	93	90		92
3	102	96	91	87	100	95	90	86	92	88	85		90	86	84		87
4	97	90	84	80	95	88	83	79	86	82	78		84	81	78		82
5	92	84	78	74	91	83	77	73	81	76	73		79	75	72		78
6	87	79	73	68	86	78	72	68	76	71	68		75	70	67		74
7	83	74	68	63	82	73	67	63	72	67	63		71	66	63		69
8	79	69	63	59	78	69	63	59	68	63	59		67	62	59		66
9	75	65	59	55	74	65	59	55	64	59	55		63	58	55		62
10	72	62	56	52	71	61	56	52	61	55	52		60	55	52		59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	253135
5°	252512
10°	260901
15°	261171
20°	240301
25°	204390
30°	155749
35°	110134
40°	64668
45°	26098
50°	8720
55°	4191
60°	1726
65°	259
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 26098 cd/sqm



TEST NUMBER: P780611

CATALOG NUMBER: LER4D25D010-EC4DR6020359027-4LBS1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	222.1	9.6
10°-20°	639.6	27.6
20°-30°	765.6	33.1
30°-40°	512.0	22.1
40°-50°	151.8	6.6
50°-60°	21.8	0.9
60°-70°	2.1	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1627.3	70.3
0°-40°	2139.3	92.4
0°-60°	2313.0	99.9
0°-90°	2315.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2315.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2317	
5°	2302	222
15°	2309	640
25°	1695	766
35°	826	512
45°	169	152
55°	22	22
65°	1	2
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P780611

CATALOG NUMBER: LER4D25D010-EC4DR6020359027-4LBS1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	2316.8
2.5°	2313.8
5°	2302.3
7.5°	2333.5
10°	2351.6
12.5°	2348.3
15°	2308.9
17.5°	2215.9
20°	2066.7
22.5°	1887.6
25°	1695.4
27.5°	1478.9
30°	1234.5
32.5°	1016.3
35°	825.7
37.5°	634.8
40°	453.4
42.5°	299.0
45°	168.9
47.5°	86.4
50°	51.3
52.5°	33.2
55°	22.0
57.5°	14.2
60°	7.9
62.5°	3.3
65°	1.0
67.5°	0.3
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)