

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P781394

Luminaire Tested: LER4D40BD010-EC4DR6040509050-4LBS1LI

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P781394
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-60)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4D40BD010-EC4DR6040509050-4LBS1LI
Description: 4 INCH ROUND SHALLOW SPECULAR CLEAR TRIM, WITH 60° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 5000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4442.1 lumens
Efficiency: N/A
Efficacy: 126.2 lumens/watt
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 35.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P781394

CATALOG NUMBER: LER4D40BD010-EC4DR6040509050-4LBS1LI

Luminous Intensity Polar Plot





TEST NUMBER: P781394

CATALOG NUMBER: LER4D40BD010-EC4DR6040509050-4LBS1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	108	106	111	109	106	104	105	103	101		101	99	98		97
2	108	103	99	96	106	101	98	95	98	95	92		95	93	90		92
3	102	96	91	87	100	95	90	86	92	88	85		90	86	84		87
4	97	90	84	80	95	88	83	79	86	82	78		84	81	78		82
5	92	84	78	74	91	83	77	73	81	76	73		79	75	72		78
6	87	79	73	68	86	78	72	68	76	71	68		75	70	67		74
7	83	74	68	63	82	73	67	63	72	67	63		71	66	63		69
8	79	69	63	59	78	69	63	59	68	63	59		67	62	59		66
9	75	65	59	55	74	65	59	55	64	59	55		63	58	55		62
10	72	62	56	52	71	61	56	52	61	55	52		60	55	52		59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	485708
5°	484525
10°	500612
15°	501134
20°	461092
25°	392192
30°	298843
35°	211332
40°	124088
45°	50079
50°	16726
55°	8039
60°	3300
65°	491
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 50079 cd/sqm



TEST NUMBER: P781394

CATALOG NUMBER: LER4D40BD010-EC4DR6040509050-4LBS1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	426.2	9.6
10°-20°	1227.3	27.6
20°-30°	1469.0	33.1
30°-40°	982.5	22.1
40°-50°	291.3	6.6
50°-60°	41.9	0.9
60°-70°	4.0	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3122.5	70.3
0°-40°	4105.0	92.4
0°-60°	4438.2	99.9
0°-90°	4442.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4442.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4445	
5°	4418	426
15°	4430	1227
25°	3253	1469
35°	1584	983
45°	324	291
55°	42	42
65°	2	4
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P781394

CATALOG NUMBER: LER4D40BD010-EC4DR6040509050-4LBS1LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	4445.4
2.5°	4439.7
5°	4417.7
7.5°	4477.6
10°	4512.2
12.5°	4505.9
15°	4430.3
17.5°	4251.9
20°	3965.6
22.5°	3622.0
25°	3253.2
27.5°	2837.7
30°	2368.7
32.5°	1950.0
35°	1584.4
37.5°	1218.1
40°	870.0
42.5°	573.7
45°	324.1
47.5°	165.8
50°	98.4
52.5°	63.7
55°	42.2
57.5°	27.1
60°	15.1
62.5°	6.3
65°	1.9
67.5°	0.6
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9





— 0°-180°







(END OF REPORT)