

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P781502

Luminaire Tested: LER4D45BD010-EC4DR3540509030-4LBS1LI

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P781502
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-20)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4D45BD010-EC4DR3540509030-4LBS1LI
Description: 4 INCH ROUND SHALLOW SPECULAR CLEAR TRIM, WITH 35° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4350.4 lumens
Efficiency: N/A
Efficacy: 112.4 lumens/watt
Spacing Criteria (0/90/45): 0.6 / 0.6 / 0.54
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 38.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P781502

CATALOG NUMBER: LER4D45BD010-EC4DR3540509030-4LBS1LI

Luminous Intensity Polar Plot





TEST NUMBER: P781502

CATALOG NUMBER: LER4D45BD010-EC4DR3540509030-4LBS1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	115	112	110	108	112	110	108	107	106	105	103		103	101	100		99
2	110	106	103	101	108	105	102	99	102	99	97		99	97	95		96
3	106	101	97	94	105	100	96	93	97	95	92		95	93	91		93
4	103	97	92	89	101	96	92	89	94	90	88		92	89	87		90
5	99	93	88	85	98	92	87	84	90	86	84		89	85	83		87
6	96	89	84	81	94	88	84	81	87	83	80		85	82	80		84
7	93	85	81	78	91	85	80	77	84	80	77		83	79	77		82
8	90	82	78	74	88	82	77	74	81	77	74		80	76	74		79
9	87	79	75	72	86	79	75	72	78	74	71		77	74	71		77
10	84	77	72	69	83	76	72	69	76	72	69		75	71	69		74

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1307840
5°	1277103
10°	1151012
15°	893371
20°	506706
25°	197133
30°	73541
35°	40308
40°	26344
45°	16039
50°	10216
55°	7220
60°	5288
65°	2870
70°	224
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 16039 cd/sqm



TEST NUMBER: P781502

CATALOG NUMBER: LER4D45BD010-EC4DR3540509030-4LBS1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1070.9	24.6
10°-20°	2090.9	48.1
20°-30°	852.7	19.6
30°-40°	204.1	4.7
40°-50°	85.1	2.0
50°-60°	35.2	0.8
60°-70°	11.0	0.3
70°-80°	0.3	0.0
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4014.5	92.3
0°-40°	4218.6	97.0
0°-60°	4338.9	99.7
0°-90°	4350.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4350.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	11970	
5°	11644	###
15°	7898	2091
25°	1635	853
35°	302	204
45°	104	85
55°	38	35
65°	11	11
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P781502

CATALOG NUMBER: LER4D45BD010-EC4DR3540509030-4LBS1LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	11969.9
2.5°	11898.1
5°	11644.1
7.5°	11137.6
10°	10374.5
12.5°	9300.0
15°	7897.9
17.5°	6183.1
20°	4357.9
22.5°	2778.8
25°	1635.2
27.5°	924.3
30°	582.9
32.5°	409.3
35°	302.2
37.5°	233.7
40°	184.7
42.5°	142.3
45°	103.8
47.5°	77.7
50°	60.1
52.5°	47.7
55°	37.9
57.5°	30.7
60°	24.2
62.5°	17.6
65°	11.1
67.5°	3.9
70°	0.7
72.5°	0.7
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.7
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9





— 0°-180°







(END OF REPORT)