

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P781738

Luminaire Tested: LER4D50D010-EC4DR3540509027-4LBS1LI

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P781738
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-20)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4D50D010-EC4DR3540509027-4LBS1LI
Description: 4 INCH ROUND SHALLOW SPECULAR CLEAR TRIM, WITH 35° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4959.2 lumens
Efficiency: N/A
Efficacy: 105.5 lumens/watt
Spacing Criteria (0/90/45): 0.6 / 0.6 / 0.54
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 47
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P781738

CATALOG NUMBER: LER4D50D010-EC4DR3540509027-4LBS1LI

Luminous Intensity Polar Plot





TEST NUMBER: P781738

CATALOG NUMBER: LER4D50D010-EC4DR3540509027-4LBS1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	115	112	110	108	112	110	108	107	106	105	103	103	101	100	99	98	98	96		
2	110	106	103	101	108	105	102	99	102	99	97	99	97	95	96	95	93	92		
3	106	101	97	94	105	100	96	93	97	95	92	95	93	91	93	91	89	88		
4	103	97	92	89	101	96	92	89	94	90	88	92	89	87	90	88	86	84		
5	99	93	88	85	98	92	87	84	90	86	84	89	85	83	87	84	82	81		
6	96	89	84	81	94	88	84	81	87	83	80	85	82	80	84	81	79	78		
7	93	85	81	78	91	85	80	77	84	80	77	83	79	77	82	79	76	75		
8	90	82	78	74	88	82	77	74	81	77	74	80	76	74	79	76	73	72		
9	87	79	75	72	86	79	75	72	78	74	71	77	74	71	77	73	71	70		
10	84	77	72	69	83	76	72	69	76	72	69	75	71	69	74	71	69	68		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1490885
5°	1455845
10°	1312106
15°	1018409
20°	577620
25°	224728
30°	83836
35°	45950
40°	30038
45°	18279
50°	11644
55°	8229
60°	6009
65°	3283
70°	224
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 18279 cd/sqm



TEST NUMBER: P781738

CATALOG NUMBER: LER4D50D010-EC4DR3540509027-4LBS1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1220.8	24.6
10°-20°	2383.5	48.1
20°-30°	972.1	19.6
30°-40°	232.6	4.7
40°-50°	97.0	2.0
50°-60°	40.1	0.8
60°-70°	12.6	0.3
70°-80°	0.3	0.0
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4576.4	92.3
0°-40°	4809.1	97.0
0°-60°	4946.2	99.7
0°-90°	4959.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4959.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	13645	
5°	13274	###
15°	9003	2384
25°	1864	972
35°	344	233
45°	118	97
55°	43	40
65°	13	13
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P781738

CATALOG NUMBER: LER4D50D010-EC4DR3540509027-4LBS1LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	13645.2
2.5°	13563.3
5°	13273.8
7.5°	12696.4
10°	11826.5
12.5°	10601.7
15°	9003.3
17.5°	7048.4
20°	4967.8
22.5°	3167.8
25°	1864.1
27.5°	1053.7
30°	664.5
32.5°	466.6
35°	344.5
37.5°	266.4
40°	210.6
42.5°	162.2
45°	118.3
47.5°	88.6
50°	68.5
52.5°	54.3
55°	43.2
57.5°	35.0
60°	27.5
62.5°	20.1
65°	12.7
67.5°	4.5
70°	0.7
72.5°	0.7
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.7
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)