

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P784811

Luminaire Tested: LER4DD40BD010-EC4DR6540509027-4LBDP1MW

Issue Date: 2/5/2024

Test Information

Test Method: LM-79-2019
Report Number: P784811
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-59)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/5/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4DD40BD010-EC4DR6540509027-4LBDP1MW
Description: 4 INCH ROUND DEEP 45° CUTOFF MATTE WHITE TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2760.7 lumens
Efficiency: N/A
Efficacy: 78.4 lumens/watt
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 35.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P784811

CATALOG NUMBER: LER4DD40BD010-EC4DR6540509027-4LBDP1MW

Luminous Intensity Polar Plot





TEST NUMBER: P784811

CATALOG NUMBER: LER4DD40BD010-EC4DR6540509027-4LBDP1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	111	108	106	111	108	106	104	104	103	101		101	99	98		97
2	108	103	99	95	106	101	97	94	98	95	92		95	92	90		92
3	102	96	91	87	100	94	90	86	92	88	85		89	86	83		87
4	97	89	84	79	95	88	83	79	86	82	78		84	80	77		82
5	92	83	78	73	90	83	77	73	81	76	72		79	75	72		77
6	87	78	72	68	86	77	72	68	76	71	67		74	70	67		73
7	83	73	67	63	81	73	67	63	71	66	62		70	66	62		69
8	79	69	63	59	77	68	63	59	67	62	58		66	62	58		65
9	75	65	59	55	74	65	59	55	64	58	55		63	58	55		62
10	71	61	56	52	70	61	55	52	60	55	51		59	55	51		59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	296982
5°	297228
10°	307687
15°	308193
20°	283752
25°	241763
30°	185082
35°	130755
40°	77177
45°	31336
50°	11355
55°	6324
60°	3627
65°	1991
70°	2108
75°	1646
80°	1699
85°	1504

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 31336 cd/sqm



TEST NUMBER: P784811

CATALOG NUMBER: LER4DD40BD010-EC4DR6540509027-4LBDP1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	261.7	9.5
10°-20°	755.0	27.3
20°-30°	905.8	32.8
30°-40°	608.7	22.1
40°-50°	182.2	6.6
50°-60°	32.2	1.2
60°-70°	9.1	0.3
70°-80°	4.5	0.2
80°-90°	1.4	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1922.5	69.6
0°-40°	2531.2	91.7
0°-60°	2745.6	99.5
0°-90°	2760.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2760.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2718	
5°	2710	262
15°	2725	755
25°	2005	906
35°	980	609
45°	203	182
55°	33	32
65°	8	9
75°	4	4
85°	1	1
90°	0	



TEST NUMBER: P784811

CATALOG NUMBER: LER4DD40BD010-EC4DR6540509027-4LBDP1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	2718.1
2.5°	2729.7
5°	2710.0
7.5°	2750.9
10°	2773.3
12.5°	2767.9
15°	2724.6
17.5°	2618.8
20°	2440.4
22.5°	2230.2
25°	2005.4
27.5°	1751.7
30°	1467.0
32.5°	1209.0
35°	980.3
37.5°	754.4
40°	541.1
42.5°	353.4
45°	202.8
47.5°	107.4
50°	66.8
52.5°	46.4
55°	33.2
57.5°	23.9
60°	16.6
62.5°	10.8
65°	7.7
67.5°	7.0
70°	6.6
72.5°	5.0
75°	3.9
77.5°	3.5
80°	2.7
82.5°	1.9
85°	1.2
87.5°	0.8
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)