

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P785150

Luminaire Tested: LER4DD50D010-EC4DR3540509030-4LBDP1LI

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P785150
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-20)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4DD50D010-EC4DR3540509030-4LBDP1LI
Description: 4 INCH ROUND DEEP 45° CUTOFF SPECULAR CLEAR TRIM, WITH 35° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4853.6 lumens
Efficiency: N/A
Efficacy: 103.3 lumens/watt
Spacing Criteria (0/90/45): 0.6 / 0.6 / 0.54
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 47
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P785150

CATALOG NUMBER: LER4DD50D010-EC4DR3540509030-4LBDP1LI

Luminous Intensity Polar Plot





TEST NUMBER: P785150

CATALOG NUMBER: LER4DD50D010-EC4DR3540509030-4LBDP1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	115	112	110	108	112	110	108	107	106	105	103		103	101	100		99
2	110	106	103	101	108	105	102	99	102	99	97		99	97	95		96
3	106	101	97	94	105	100	96	93	97	95	92		95	93	91		93
4	103	97	92	89	101	96	92	89	94	90	88		92	89	87		90
5	99	93	88	85	98	92	87	84	90	86	84		89	85	83		87
6	96	89	84	81	94	88	84	81	87	83	80		85	82	80		84
7	93	85	81	78	91	85	80	77	84	80	77		83	79	77		82
8	90	82	78	74	88	82	77	74	81	77	74		80	76	74		79
9	87	79	75	72	86	79	75	72	78	74	71		77	74	71		77
10	84	77	72	69	83	76	72	69	76	72	69		75	71	69		74

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1459134
5°	1424850
10°	1284170
15°	996725
20°	565330
25°	219942
30°	82057
35°	44977
40°	29396
45°	17893
50°	11389
55°	8039
60°	5878
65°	3206
70°	224
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 17893 cd/sqm

TEST NUMBER: P785150

CATALOG NUMBER: LER4DD50D010-EC4DR3540509030-4LBDP1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1194.8	24.6
10°-20°	2332.8	48.1
20°-30°	951.4	19.6
30°-40°	227.7	4.7
40°-50°	94.9	2.0
50°-60°	39.3	0.8
60°-70°	12.3	0.3
70°-80°	0.3	0.0
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4479.0	92.3
0°-40°	4706.7	97.0
0°-60°	4840.8	99.7
0°-90°	4853.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4853.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	13355	
5°	12991	###
15°	8812	2333
25°	1824	951
35°	337	228
45°	116	95
55°	42	39
65°	12	12
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P785150

CATALOG NUMBER: LER4DD50D010-EC4DR3540509030-4LBDP1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	13354.6
2.5°	13274.5
5°	12991.2
7.5°	12426.1
10°	11574.7
12.5°	10375.9
15°	8811.6
17.5°	6898.4
20°	4862.1
22.5°	3100.3
25°	1824.4
27.5°	1031.3
30°	650.4
32.5°	456.6
35°	337.2
37.5°	260.7
40°	206.1
42.5°	158.8
45°	115.8
47.5°	86.7
50°	67.0
52.5°	53.2
55°	42.2
57.5°	34.2
60°	26.9
62.5°	19.7
65°	12.4
67.5°	4.4
70°	0.7
72.5°	0.7
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.7
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9





— 0°-180°







(END OF REPORT)