

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P785302

Luminaire Tested: LER4DD50D010-EC4DR6540509040-4LBDP1LI

Issue Date: 2/5/2024

Test Information

Test Method: LM-79-2019
Report Number: P785302
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-59)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/5/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER4DD50D010-EC4DR6540509040-4LBDP1LI
Description: 4 INCH ROUND DEEP 45° CUTOFF SPECULAR CLEAR TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4709.9 lumens
Efficiency: N/A
Efficacy: 100.2 lumens/watt
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 47
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P785302

CATALOG NUMBER: LER4DD50D010-EC4DR6540509040-4LBDP1LI

Luminous Intensity Polar Plot





TEST NUMBER: P785302

CATALOG NUMBER: LER4DD50D010-EC4DR6540509040-4LBDP1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	113	111	108	106		111	108	106	104		104	103	101		101	99	98		97	96	95
2	108	103	99	95		106	101	97	94		98	95	92		95	92	90		92	90	88
3	102	96	91	87		100	94	90	86		92	88	85		89	86	83		87	84	82
4	97	89	84	79		95	88	83	79		86	82	78		84	80	77		82	79	76
5	92	83	78	73		90	83	77	73		81	76	72		79	75	72		77	74	71
6	87	78	72	68		86	77	72	68		76	71	67		74	70	67		73	69	66
7	83	73	67	63		81	73	67	63		71	66	62		70	66	62		69	65	62
8	79	69	63	59		77	68	63	59		67	62	58		66	62	58		65	61	58
9	75	65	59	55		74	65	59	55		64	58	55		63	58	55		62	58	54
10	71	61	56	52		70	61	55	52		60	55	51		59	55	51		59	54	51

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	506664
5°	507086
10°	524931
15°	525804
20°	484090
25°	412470
30°	315762
35°	223083
40°	131676
45°	53463
50°	19378
55°	10801
60°	6184
65°	3413
70°	3578
75°	2786
80°	2894
85°	2507

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 53463 cd/sqm

TEST NUMBER: P785302

CATALOG NUMBER: LER4DD50D010-EC4DR6540509040-4LBDP1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	446.5	9.5
10°-20°	1288.0	27.3
20°-30°	1545.4	32.8
30°-40°	1038.5	22.1
40°-50°	310.9	6.6
50°-60°	54.9	1.2
60°-70°	15.6	0.3
70°-80°	7.6	0.2
80°-90°	2.4	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3279.9	69.6
0°-40°	4318.4	91.7
0°-60°	4684.2	99.5
0°-90°	4709.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4709.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4637	
5°	4623	447
15°	4648	1288
25°	3421	1545
35°	1672	1039
45°	346	311
55°	57	55
65°	13	16
75°	7	8
85°	2	2
90°	0	



TEST NUMBER: P785302

CATALOG NUMBER: LER4DD50D010-EC4DR6540509040-4LBDP1LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	4637.2
2.5°	4657.0
5°	4623.4
7.5°	4693.2
10°	4731.4
12.5°	4722.2
15°	4648.4
17.5°	4467.8
20°	4163.4
22.5°	3804.9
25°	3421.4
27.5°	2988.4
30°	2502.8
32.5°	2062.6
35°	1672.5
37.5°	1287.0
40°	923.2
42.5°	603.0
45°	346.0
47.5°	183.2
50°	114.0
52.5°	79.1
55°	56.7
57.5°	40.9
60°	28.3
62.5°	18.5
65°	13.2
67.5°	11.9
70°	11.2
72.5°	8.6
75°	6.6
77.5°	5.9
80°	4.6
82.5°	3.3
85°	2.0
87.5°	1.3
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9





— 0°-180°







(END OF REPORT)