

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P1191690

Luminaire Tested: **LDA4A25927D010TE LAR15SP 4LA1**

Issue Date: 3/3/2020

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

**Test Information**

Test Method: LM-41-14
Report Number: P1191690
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P25628)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LDA4A25927D010TE LAR15SP 4LA1
Description: PORTFOLIO 4" Adjustable Reflector, Self-flange Trim Ring, 15° Spot
Optic, at 0° tilt
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1919.6 lumens
Efficiency: N/A
Efficacy: 62.1 lumens/watt
Spacing Criteria (0/90/45): 0.32 / 0.32 / 0.35
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 30.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P1191690

CATALOG NUMBER: LDA4A25927D010TE LAR15SP 4LA1

Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P1191690

CATALOG NUMBER: LDA4A25927D010TE LAR15SP 4LA1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	115	113	112	110	113	111	110	108	107	106	105	104	103	102	100	100	99	97		
2	112	109	106	104	110	107	105	102	104	102	100	101	100	98	98	97	96	95		
3	109	105	101	99	107	103	100	98	101	98	96	99	97	95	97	95	94	92		
4	106	101	97	95	104	100	97	94	98	95	93	96	94	92	95	93	91	90		
5	103	98	94	91	102	97	94	91	95	92	90	94	91	89	93	90	89	88		
6	101	95	91	89	99	94	91	88	93	90	88	92	89	87	91	88	87	86		
7	98	92	89	86	97	92	88	86	91	88	85	90	87	85	89	86	85	84		
8	96	90	86	84	95	90	86	84	89	86	83	88	85	83	87	85	83	82		
9	94	88	84	82	93	87	84	82	87	84	81	86	83	81	85	83	81	80		
10	92	86	82	80	91	85	82	80	85	82	80	84	81	79	84	81	79	78		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1541278
5°	1285825
10°	699074
15°	371342
20°	211541
25°	41401
30°	8560
35°	2545
40°	966
45°	419
50°	230
55°	258
60°	296
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P1191690
 CATALOG NUMBER: LDA4A25927D010TE LAR15SP 4LA1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	823.3	42.9
10°-20°	838.8	43.7
20°-30°	240.6	12.5
30°-40°	13.6	0.7
40°-50°	2.0	0.1
50°-60°	1.1	0.1
60°-70°	0.1	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1902.7	99.1
0°-40°	1916.3	99.8
0°-60°	1919.4	100.0
0°-90°	1919.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1919.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	12496	
5°	10385	823
15°	2908	839
25°	304	241
35°	17	14
45°	2	2
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P1191690

CATALOG NUMBER: LDA4A25927D010TE LAR15SP 4LA1

CANDELA DISTRIBUTION (FULL):

	0°
0°	12495.6
2.5°	11978.4
5°	10384.9
7.5°	7779.9
10°	5581.5
12.5°	4025.3
15°	2908.0
17.5°	2104.6
20°	1611.6
22.5°	1016.3
25°	304.2
27.5°	116.7
30°	60.1
32.5°	31.2
35°	16.9
37.5°	9.6
40°	6.0
42.5°	3.6
45°	2.4
47.5°	1.2
50°	1.2
52.5°	1.2
55°	1.2
57.5°	1.2
60°	1.2
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Classified

Scaled Data Report

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)