

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P1191884

Luminaire Tested: **LDA4A35927D010TE LAR35FL 4LAL1**

Issue Date: 3/3/2020

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

**Test Information**

Test Method: LM-41-14
Report Number: P1191884
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P26146)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LDA4A35927D010TE LAR35FL 4LAL1
Description: PORTFOLIO 4" Lensed Adjustable, Self-flange Trim Ring, 35° Flood Optic, at 0° tilt
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3252.0 lumens
Efficiency: N/A
Efficacy: 69.0 lumens/watt
Spacing Criteria (0/90/45): 0.58 / 0.58 / 0.55
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 47.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P1191884

CATALOG NUMBER: LDA4A35927D010TE LAR35FL 4LAL1

Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P1191884

CATALOG NUMBER: LDA4A35927D010TE LAR35FL 4LAL1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100
1	115	113	111	109	113	111	109	107	107	105	104	103	102	101	100	99	98	96	96	96
2	111	107	104	102	109	106	103	100	102	100	98	100	98	96	97	96	94	93	93	93
3	107	103	99	96	105	101	98	95	99	96	94	96	94	92	94	92	91	90	90	90
4	104	98	94	91	102	97	93	91	95	92	90	93	91	89	92	89	88	86	86	86
5	101	94	90	87	99	94	90	87	92	89	86	90	88	85	89	87	85	83	83	83
6	97	91	87	83	96	90	86	83	89	85	83	88	85	82	86	84	82	81	81	81
7	94	88	83	80	93	87	83	80	86	82	80	85	82	79	84	81	79	78	78	78
8	92	85	80	77	91	84	80	77	83	80	77	82	79	77	82	79	76	75	75	75
9	89	82	78	75	88	82	77	75	81	77	74	80	77	74	79	76	74	73	73	73
10	86	79	75	72	86	79	75	72	78	75	72	78	74	72	77	74	72	71	71	71

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1279760
5°	1173115
10°	989387
15°	802268
20°	519534
25°	149802
30°	32730
35°	9276
40°	3494
45°	1448
50°	633
55°	366
60°	419
65°	496
70°	613
75°	0
80°	0
85°	0



TEST NUMBER: P1191884

CATALOG NUMBER: LDA4A35927D010TE LAR35FL 4LAL1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	853.7	26.3
10°-20°	1685.6	51.8
20°-30°	649.3	20.0
30°-40°	51.4	1.6
40°-50°	7.4	0.2
50°-60°	1.7	0.1
60°-70°	1.7	0.1
70°-80°	0.7	0.0
80°-90°	0.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3188.6	98.1
0°-40°	3240.1	99.6
0°-60°	3249.1	99.9
0°-90°	3252.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3252.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	10375	
5°	9475	854
15°	6283	1686
25°	1101	649
35°	62	51
45°	8	7
55°	2	2
65°	2	2
75°	0	1
85°	0	1
90°	0	



TEST NUMBER: P1191884

CATALOG NUMBER: LDA4A35927D010TE LAR35FL 4LAL1

CANDELA DISTRIBUTION (FULL):

	0°
0°	10375.4
1°	10292.2
2°	10207.3
3°	10007.4
4°	9744.3
5°	9474.6
6°	9178.2
7°	8890.2
8°	8572.1
9°	8227.4
10°	7899.4
11°	7586.4
12°	7260.0
13°	6948.7
14°	6630.5
15°	6282.6
17.5°	5260.1
20°	3958.0
22.5°	2446.1
25°	1100.7
27.5°	423.0
30°	229.8
32.5°	118.3
35°	61.6
37.5°	36.6
40°	21.7
42.5°	13.3
45°	8.3
47.5°	5.0
50°	3.3
52.5°	1.7
55°	1.7
57.5°	1.7
60°	1.7
62.5°	1.7
65°	1.7
67.5°	1.7
70°	1.7
72.5°	0.0
75°	0.0
77.5°	1.7
80°	0.0
82.5°	0.0

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



TEST NUMBER: P1191884
CATALOG NUMBER: LDA4A35927D010TE LAR35FL 4LAL1

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0

Classified

Scaled Data Report

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



85°	0.0
87.5°	1.7

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)