

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211398

Luminaire Tested: **LE_4B15D010 EC4B10208050 4LBS1B**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211398
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LE_4B15D010 EC4B10208050 4LBS1B
Description: PORTFOLIO 4 INCH CYLINDER
SHALLOW DISTRIBUTION WITH SPECULAR BLACK TRIM
WATTAGE D010TR-14.39W DE010-14.29W D5LT-14.34W DMX-14.46W DL2-15.8W
DL3-15.28W DLE-15.432W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1550.2 lumens
Efficiency: N/A
Efficacy: 108.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.2 / 1.3
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211398

CATALOG NUMBER: LE_4B15D010 EC4B10208050 4LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P211398

CATALOG NUMBER: LE_4B15D010 EC4B10208050 4LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	111	107	103	100	108	105	101	98	100	98	95	97	94	93	93	91	90	88		
2	102	95	89	84	100	93	88	83	90	85	81	86	83	79	84	80	78	76		
3	94	84	77	72	91	83	76	71	80	74	70	77	73	68	75	71	67	65		
4	86	76	68	62	84	74	67	61	72	65	60	70	64	60	68	63	59	57		
5	80	68	60	54	78	67	59	53	65	58	53	63	57	52	61	56	52	50		
6	74	62	53	47	72	61	53	47	59	52	47	57	51	46	56	50	46	44		
7	69	56	48	42	67	55	48	42	54	47	42	52	46	41	51	45	41	39		
8	64	51	43	38	63	51	43	38	49	42	37	48	42	37	47	41	37	35		
9	60	47	39	34	59	47	39	34	46	39	34	45	38	34	44	38	34	32		
10	56	44	36	31	55	43	36	31	42	36	31	41	35	31	40	35	31	29		

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211398

CATALOG NUMBER: LE_4B15D010 EC4B10208050 4LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	64.5	4.2
10°-20°	183.1	11.8
20°-30°	272.4	17.6
30°-40°	317.0	20.4
40°-50°	309.0	19.9
50°-60°	237.7	15.3
60°-70°	131.4	8.5
70°-80°	34.8	2.2
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	520.1	33.6
0°-40°	837.1	54.0
0°-60°	1383.8	89.3
0°-90°	1550.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1550.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	684	
5°	680	65
15°	648	183
25°	592	272
35°	509	317
45°	401	309
55°	265	238
65°	132	131
75°	30	35
85°	0	0
90°	0	



TEST NUMBER: P211398

CATALOG NUMBER: LE_4B15D010 EC4B10208050 4LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	683.8
2.5°	683.8
5°	679.9
7.5°	674.1
10°	670.1
12.5°	658.3
15°	648.4
17.5°	638.7
20°	624.9
22.5°	611.1
25°	591.5
27.5°	571.9
30°	552.2
32.5°	530.6
35°	509.0
37.5°	481.4
40°	457.9
42.5°	432.3
45°	400.9
47.5°	371.4
50°	338.0
52.5°	302.6
55°	265.3
57.5°	229.9
60°	196.5
62.5°	163.1
65°	131.7
67.5°	102.2
70°	74.7
72.5°	51.0
75°	29.5
77.5°	13.8
80°	2.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)