

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P432121

Luminaire Tested: **LAM4B108R209027DE010x1MB**

Issue Date: 11/23/2020

Test Information

Test Method: LM-41-14
Report Number: P432121
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2007-857-3)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 11/23/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LAM4B108R209027DE010x1MB
Description: PORTFOLIO 4INCH ADJUSTABLE MULTIPLE, 20 DEG TIR OPTIC
Light Source: HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 764.9 lumens
Efficiency: N/A
Efficacy: 67.1 lumens/watt
Spacing Criteria (0/90/45): 0.34 / 0.34 / 0.33
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 11.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P432121

CATALOG NUMBER: LAM4B108R209027DE010x1MB

Luminous Intensity Polar Plot





TEST NUMBER: P432121

CATALOG NUMBER: LAM4B108R209027DE010x1MB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	115	113	111	110		113	111	109	108		107	106	105		103	102	102		100	99	99
2	112	108	105	103		110	106	104	102		103	101	100		101	99	97		98	97	95
3	108	104	100	98		107	103	100	97		100	98	96		98	96	94		96	94	93
4	105	100	97	94		104	99	96	93		97	94	92		96	93	91		94	92	90
5	103	97	93	90		101	96	93	90		95	92	89		93	91	89		92	90	88
6	100	94	90	88		99	94	90	87		92	89	87		91	88	86		90	88	86
7	98	92	88	85		97	91	88	85		90	87	85		89	86	84		88	86	84
8	96	90	86	83		95	89	86	83		88	85	83		87	85	82		87	84	82
9	94	88	84	81		93	87	84	81		86	83	81		86	83	81		85	82	81
10	92	86	82	80		91	85	82	80		85	82	79		84	81	79		83	81	79

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2642294
5°	2233443
10°	1311844
15°	469717
20°	155413
25°	61842
30°	29568
35°	16925
40°	12173
45°	10257
50°	11820
55°	9634
60°	4835
65°	4086
70°	5049
75°	5338
80°	3978
85°	3963



TEST NUMBER: P432121

CATALOG NUMBER: LAM4B108R209027DE010x1MB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	369.3	48.3
10°-20°	288.0	37.6
20°-30°	59.8	7.8
30°-40°	18.8	2.5
40°-50°	12.1	1.6
50°-60°	9.7	1.3
60°-70°	3.8	0.5
70°-80°	2.9	0.4
80°-90°	0.6	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	717.0	93.7
0°-40°	735.8	96.2
0°-60°	757.6	99.1
0°-90°	764.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	764.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5356	
5°	4510	369
15°	920	288
25°	114	60
35°	28	19
45°	15	12
55°	11	10
65°	4	4
75°	3	3
85°	1	1
90°	0	



TEST NUMBER: P432121

CATALOG NUMBER: LAM4B108R209027DE010x1MB

CANDELA DISTRIBUTION (FULL):

0°	
0°	5355.5
2.5°	5159.1
5°	4509.6
7.5°	3613.1
10°	2618.5
12.5°	1651.9
15°	919.6
17.5°	505.7
20°	296.0
22.5°	181.0
25°	113.6
27.5°	75.1
30°	51.9
32.5°	36.5
35°	28.1
37.5°	22.4
40°	18.9
42.5°	16.1
45°	14.7
47.5°	14.7
50°	15.4
52.5°	14.7
55°	11.2
57.5°	7.7
60°	4.9
62.5°	4.2
65°	3.5
67.5°	3.5
70°	3.5
72.5°	3.5
75°	2.8
77.5°	2.1
80°	1.4
82.5°	0.7
85°	0.7
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)