

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P432105

Luminaire Tested: **LAM4B108R159035DE010x1MW**

Issue Date: 11/23/2020

Test Information

Test Method: LM-41-14
Report Number: P432105
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1911-585-6)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 11/23/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LAM4B108R159035DE010x1MW
Description: PORTFOLIO 4INCH ADJUSTABLE MULTIPLE, 15 DEG TIR OPTIC
Light Source: HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 817.2 lumens
Efficiency: N/A
Efficacy: 71.7 lumens/watt
Spacing Criteria (0/90/45): 0.3 / 0.3 / 0.29
Luminous Opening: Circular (Dia: 0.29' x H: 0')
CIE Type: Direct


Input Watts (W): 11.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P432105

CATALOG NUMBER: LAM4B108R159035DE010x1MW

Luminous Intensity Polar Plot





TEST NUMBER: P432105

CATALOG NUMBER: LAM4B108R159035DE010x1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10		50	30	10			50	30	10			50
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111			106	106	106			102
1	116	114	112	111	113	112	110	109		108	107	106			104	103	103			101
2	113	110	107	105	111	108	106	104		105	103	102			102	101	100			100
3	110	106	103	101	108	105	102	100		103	100	98			100	99	97			98
4	108	103	100	97	106	102	99	97		100	98	96			98	96	95			97
5	105	101	97	95	104	100	97	94		98	96	94			97	95	93			95
6	103	98	95	92	102	98	94	92		96	94	92			95	93	91			94
7	101	96	93	90	100	96	92	90		95	92	90			94	91	89			93
8	99	94	91	89	99	94	91	89		93	90	88			92	90	88			91
9	98	92	89	87	97	92	89	87		91	89	87			91	88	87			90
10	96	91	88	86	95	91	88	86		90	87	85			89	87	85			89

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1168969
5°	986568
10°	453240
15°	141335
20°	57588
25°	18896
30°	5860
35°	1239
40°	315
45°	0
50°	0
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P432105

CATALOG NUMBER: LAM4B108R159035DE010x1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	470.7	57.6
10°-20°	280.6	34.3
20°-30°	59.4	7.3
30°-40°	6.3	0.8
40°-50°	0.2	0.0
50°-60°	0.0	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	810.8	99.2
0°-40°	817.0	100.0
0°-60°	817.2	100.0
0°-90°	817.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	817.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	7256	
5°	6100	471
15°	847	281
25°	106	59
35°	6	6
45°	0	0
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P432105

CATALOG NUMBER: LAM4B108R159035DE010x1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	7256.0
2.5°	7026.7
5°	6100.5
7.5°	4516.1
10°	2770.6
12.5°	1478.5
15°	847.4
17.5°	532.2
20°	335.9
22.5°	198.1
25°	106.3
27.5°	60.0
30°	31.5
32.5°	15.9
35°	6.3
37.5°	3.3
40°	1.5
42.5°	0.4
45°	0.0
47.5°	0.0
50°	0.0
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)