

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P432330

Luminaire Tested: **LAM4B108R609727DE010x1MW**

Issue Date: 11/23/2020

Test Information

Test Method: LM-41-14
Report Number: P432330
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2009-969-1)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 11/23/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LAM4B108R609727DE010x1MW
Description: PORTFOLIO 4INCH ADJUSTABLE MULTIPLE, 60 DEG TIR OPTIC
Light Source: HIGH LUMEN LED 97CRI / 2700K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 638.5 lumens
Efficiency: N/A
Efficacy: 56.0 lumens/watt
Spacing Criteria (0/90/45): 0.96 / 0.96 / 0.89
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 11.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P432330

CATALOG NUMBER: LAM4B108R609727DE010x1MW

Luminous Intensity Polar Plot





TEST NUMBER: P432330

CATALOG NUMBER: LAM4B108R609727DE010x1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	109	106	111	109	107	105	105	103	102		101	100	99		98
2	108	104	100	96	106	102	98	95	99	96	93		96	93	91		93
3	103	97	92	88	101	96	91	88	93	89	86		91	87	85		88
4	98	91	85	81	96	90	85	81	88	83	80		86	82	79		84
5	93	85	80	75	92	84	79	75	83	78	74		81	77	74		79
6	89	80	74	70	87	79	74	70	78	73	69		76	72	69		75
7	84	75	70	66	83	75	69	65	74	69	65		72	68	65		71
8	80	71	65	61	79	71	65	61	70	65	61		69	64	61		68
9	77	67	62	58	76	67	61	58	66	61	57		65	60	57		64
10	73	64	58	54	72	63	58	54	62	58	54		62	57	54		61

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	362091
5°	349954
10°	346686
15°	338088
20°	311981
25°	279432
30°	216203
35°	129496
40°	49786
45°	18211
50°	691
55°	516
60°	592
65°	350
70°	433
75°	572
80°	852
85°	0



TEST NUMBER: P432330

CATALOG NUMBER: LAM4B108R609727DE010x1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	67.1	10.5
10°-20°	184.1	28.8
20°-30°	229.7	36.0
30°-40°	133.8	21.0
40°-50°	22.3	3.5
50°-60°	0.6	0.1
60°-70°	0.4	0.1
70°-80°	0.3	0.0
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	481.0	75.3
0°-40°	614.8	96.3
0°-60°	637.7	99.9
0°-90°	638.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	638.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	734	
5°	707	67
15°	662	184
25°	513	230
35°	215	134
45°	26	22
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P432330

CATALOG NUMBER: LAM4B108R609727DE010x1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	733.9
2.5°	721.8
5°	706.6
7.5°	697.9
10°	692.0
12.5°	682.4
15°	661.9
17.5°	631.2
20°	594.2
22.5°	556.7
25°	513.3
27.5°	453.1
30°	379.5
32.5°	297.3
35°	215.0
37.5°	135.6
40°	77.3
42.5°	45.3
45°	26.1
47.5°	9.0
50°	0.9
52.5°	0.6
55°	0.6
57.5°	0.6
60°	0.6
62.5°	0.6
65°	0.3
67.5°	0.3
70°	0.3
72.5°	0.3
75°	0.3
77.5°	0.3
80°	0.3
82.5°	0.3
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)