

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P432428

Luminaire Tested: **LAM4B208R159730DE010x1MMS**

Issue Date: 11/23/2020

Test Information

Test Method: LM-41-14
Report Number: P432428
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1911-585-6)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 11/23/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LAM4B208R159730DE010x1MMS
Description: PORTFOLIO 4INCH ADJUSTABLE MULTIPLE, 15 DEG TIR OPTIC
Light Source: HIGH LUMEN LED 97CRI / 3000K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1449.2 lumens
Efficiency: N/A
Efficacy: 70.3 lumens/watt
Spacing Criteria (0/90/45): 0.3 / 0.3 / 0.29
Luminous Opening: Circular (Dia: 0.29' x H: 0')
CIE Type: Direct


Input Watts (W): 20.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P432428

CATALOG NUMBER: LAM4B208R159730DE010x1MMS

Luminous Intensity Polar Plot





TEST NUMBER: P432428

CATALOG NUMBER: LAM4B208R159730DE010x1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	116	114	112	111	113	112	110	109	108	107	106	104	103	103	101	100	100	98		
2	113	110	107	105	111	108	106	104	105	103	102	102	101	100	100	99	98	96		
3	110	106	103	101	108	105	102	100	103	100	98	100	99	97	98	97	96	94		
4	108	103	100	97	106	102	99	97	100	98	96	98	96	95	97	95	94	93		
5	105	101	97	95	104	100	97	94	98	96	94	97	95	93	95	94	92	91		
6	103	98	95	92	102	98	94	92	96	94	92	95	93	91	94	92	91	90		
7	101	96	93	90	100	96	92	90	95	92	90	94	91	89	93	91	89	88		
8	99	94	91	89	99	94	91	89	93	90	88	92	90	88	91	89	88	87		
9	98	92	89	87	97	92	89	87	91	89	87	91	88	87	90	88	86	86		
10	96	91	88	86	95	91	88	86	90	87	85	89	87	85	89	87	85	84		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2072971
5°	1749511
10°	803762
15°	250631
20°	102129
25°	33507
30°	10380
35°	2203
40°	547
45°	0
50°	0
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P432428

CATALOG NUMBER: LAM4B208R159730DE010x1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	834.8	57.6
10°-20°	497.5	34.3
20°-30°	105.4	7.3
30°-40°	11.1	0.8
40°-50°	0.4	0.0
50°-60°	0.0	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1437.7	99.2
0°-40°	1448.8	100.0
0°-60°	1449.2	100.0
0°-90°	1449.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1449.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	12867	
5°	10818	835
15°	1503	498
25°	188	105
35°	11	11
45°	0	0
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P432428

CATALOG NUMBER: LAM4B208R159730DE010x1MMS

CANDELA DISTRIBUTION (FULL):

	0°
0°	12867.3
2.5°	12460.8
5°	10818.2
7.5°	8008.6
10°	4913.3
12.5°	2621.8
15°	1502.7
17.5°	943.8
20°	595.7
22.5°	351.4
25°	188.5
27.5°	106.4
30°	55.8
32.5°	28.2
35°	11.2
37.5°	5.9
40°	2.6
42.5°	0.7
45°	0.0
47.5°	0.0
50°	0.0
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)