

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P434117

Luminaire Tested: **LAMR4B308R459030DE01021MMS**

Issue Date: 11/23/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P434117  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2008-908-8)  
Test Lab: INNOVATION CENTER (G2)  
Issue Date: 11/23/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LAMR4B308R459030DE01021MMS  
Description: PORTFOLIO 4INCH ADJUSTABLE MULTIPLE, 45 DEG TIR OPTIC  
Light Source: HIGH LUMEN LED 90CRI / 3000K CCT  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2400.6 lumens  
Efficiency: N/A  
Efficacy: 75.3 lumens/watt  
Spacing Criteria (0/90/45): 0.73 / 0.73 / 0.66  
Luminous Opening: Circular (Dia: 0.17' x H: 0')  
CIE Type: Direct


Input Watts (W): 31.9  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P434117

CATALOG NUMBER: LAMR4B308R459030DE01021MMS

### Luminous Intensity Polar Plot





TEST NUMBER: P434117

CATALOG NUMBER: LAMR4B308R459030DE01021MMS

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |  | 20  |     |     |  | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |  | 30  |     |     |  | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 |
| 1   | 114 | 112 | 109 | 107 | 112 | 109 | 107 | 105 | 105 | 104 | 102 |  | 102 | 100 | 99  |  | 98  |
| 2   | 109 | 105 | 101 | 98  | 107 | 103 | 100 | 97  | 100 | 97  | 95  |  | 97  | 95  | 93  |  | 94  |
| 3   | 105 | 99  | 94  | 91  | 103 | 98  | 93  | 90  | 95  | 92  | 89  |  | 93  | 90  | 87  |  | 90  |
| 4   | 100 | 94  | 89  | 85  | 99  | 93  | 88  | 85  | 90  | 87  | 84  |  | 89  | 85  | 83  |  | 87  |
| 5   | 96  | 89  | 84  | 80  | 95  | 88  | 83  | 80  | 86  | 82  | 79  |  | 85  | 81  | 78  |  | 83  |
| 6   | 92  | 85  | 79  | 76  | 91  | 84  | 79  | 75  | 82  | 78  | 75  |  | 81  | 77  | 74  |  | 80  |
| 7   | 89  | 81  | 75  | 72  | 87  | 80  | 75  | 72  | 79  | 74  | 71  |  | 78  | 74  | 71  |  | 77  |
| 8   | 85  | 77  | 72  | 68  | 84  | 77  | 72  | 68  | 76  | 71  | 68  |  | 75  | 71  | 68  |  | 74  |
| 9   | 82  | 74  | 69  | 65  | 81  | 73  | 68  | 65  | 72  | 68  | 65  |  | 72  | 68  | 65  |  | 71  |
| 10  | 79  | 71  | 66  | 62  | 78  | 70  | 66  | 62  | 70  | 65  | 62  |  | 69  | 65  | 62  |  | 68  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |         |
|-----|---------|
|     | 0°      |
| 0°  | 2218333 |
| 5°  | 2217595 |
| 10° | 2107818 |
| 15° | 1851541 |
| 20° | 1416410 |
| 25° | 826865  |
| 30° | 338462  |
| 35° | 143108  |
| 40° | 77996   |
| 45° | 50377   |
| 50° | 39376   |
| 55° | 34063   |
| 60° | 27629   |
| 65° | 21714   |
| 70° | 20196   |
| 75° | 17728   |
| 80° | 19889   |
| 85° | 13020   |



TEST NUMBER: P434117

CATALOG NUMBER: LAMR4B308R459030DE01021MMS

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 419.0  | 17.5      |
| 10°-20°   | 986.9  | 41.1      |
| 20°-30°   | 695.3  | 29.0      |
| 30°-40°   | 171.1  | 7.1       |
| 40°-50°   | 59.7   | 2.5       |
| 50°-60°   | 35.4   | 1.5       |
| 60°-70°   | 19.6   | 0.8       |
| 70°-80°   | 10.7   | 0.4       |
| 80°-90°   | 2.9    | 0.1       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 2101.2 | 87.5      |
| 0°-40°    | 2272.3 | 94.7      |
| 0°-60°    | 2367.4 | 98.6      |
| 0°-90°    | 2400.6 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 2400.6 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 4496 |      |
| 5°  | 4478 | 419  |
| 15° | 3625 | 987  |
| 25° | 1519 | 695  |
| 35° | 238  | 171  |
| 45° | 72   | 60   |
| 55° | 40   | 35   |
| 65° | 19   | 20   |
| 75° | 9    | 11   |
| 85° | 2    | 3    |
| 90° | 0    |      |



TEST NUMBER: P434117

CATALOG NUMBER: LAMR4B308R459030DE01021MMS

**CANDELA DISTRIBUTION (FULL):**

|       | 0°     |
|-------|--------|
| 0°    | 4496.2 |
| 2.5°  | 4484.6 |
| 5°    | 4477.6 |
| 7.5°  | 4396.0 |
| 10°   | 4207.3 |
| 12.5° | 3951.1 |
| 15°   | 3624.9 |
| 17.5° | 3203.3 |
| 20°   | 2697.7 |
| 22.5° | 2117.6 |
| 25°   | 1518.9 |
| 27.5° | 980.8  |
| 30°   | 594.1  |
| 32.5° | 361.1  |
| 35°   | 237.6  |
| 37.5° | 167.7  |
| 40°   | 121.1  |
| 42.5° | 93.2   |
| 45°   | 72.2   |
| 47.5° | 60.6   |
| 50°   | 51.3   |
| 52.5° | 44.3   |
| 55°   | 39.6   |
| 57.5° | 34.9   |
| 60°   | 28.0   |
| 62.5° | 23.3   |
| 65°   | 18.6   |
| 67.5° | 16.3   |
| 70°   | 14.0   |
| 72.5° | 11.6   |
| 75°   | 9.3    |
| 77.5° | 9.3    |
| 80°   | 7.0    |
| 82.5° | 4.7    |
| 85°   | 2.3    |
| 87.5° | 0.0    |
| 90°   | 0.0    |



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)