

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211412

Luminaire Tested: **LE_4B15D010 EC4B10209050 4LBCS1MMS**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211412
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LE_4B15D010 EC4B10209050 4LBCS1MMS
Description: PORTFOLIO 4 INCH CYLINDER
SHALLOW DISTRIBUTION WITH CAST MATTE BLACK TRIM
WATTAGE D010TR-14.39W DE010-14.29W D5LT-14.34W DMX-14.46W DL2-15.8W
DL3-15.28W DLE-15.432W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1332.2 lumens
Efficiency: N/A
Efficacy: 93.2 lumens/watt
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.27
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211412

CATALOG NUMBER: LE_4B15D010 EC4B10209050 4LBCS1MMS

Luminous Intensity Polar Plot






TEST NUMBER: P211412

CATALOG NUMBER: LE_4B15D010 EC4B10209050 4LBCS1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					0
RW	70	50	30	10	70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111		106	106	106		102	102	102
1	111	107	103	100	108	105	101	98		100	98	95		97	94	92		93	91	90
2	102	95	89	84	100	93	88	83		90	85	81		86	83	79		83	80	78
3	94	85	77	72	92	83	76	71		80	74	70		77	73	69		75	71	67
4	87	76	68	62	84	74	67	61		72	66	61		70	64	60		68	63	59
5	80	68	60	54	78	67	59	54		65	58	53		63	57	53		61	56	52
6	74	62	54	48	72	61	53	47		59	52	47		58	51	47		56	51	46
7	69	56	48	42	67	56	48	42		54	47	42		53	46	42		51	46	41
8	64	52	44	38	63	51	43	38		50	43	38		48	42	38		47	42	37
9	60	48	40	35	59	47	40	34		46	39	34		45	39	34		44	38	34
10	57	44	36	31	55	43	36	31		43	36	31		42	35	31		41	35	31

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211412

CATALOG NUMBER: LE_4B15D010 EC4B10209050 4LBCS1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	57.7	4.3
10°-20°	161.8	12.1
20°-30°	236.3	17.7
30°-40°	270.3	20.3
40°-50°	259.7	19.5
50°-60°	200.6	15.1
60°-70°	112.0	8.4
70°-80°	32.6	2.4
80°-90°	1.4	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	455.7	34.2
0°-40°	726.0	54.5
0°-60°	1186.3	89.0
0°-90°	1332.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1332.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	612	
5°	607	58
15°	574	162
25°	514	236
35°	433	270
45°	339	260
55°	225	201
65°	112	112
75°	28	33
85°	1	1
90°	0	



TEST NUMBER: P211412

CATALOG NUMBER: LE_4B15D010 EC4B10209050 4LBCS1MMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	611.8
2.5°	611.8
5°	606.6
7.5°	604.0
10°	595.4
12.5°	585.1
15°	573.9
17.5°	562.6
20°	546.2
22.5°	533.4
25°	513.5
27.5°	493.7
30°	473.9
32.5°	454.1
35°	432.6
37.5°	411.0
40°	386.0
42.5°	363.7
45°	338.6
47.5°	310.2
50°	283.5
52.5°	254.2
55°	224.9
57.5°	194.8
60°	166.3
62.5°	137.8
65°	112.1
67.5°	87.9
70°	65.5
72.5°	45.7
75°	28.4
77.5°	14.6
80°	5.2
82.5°	1.7
85°	0.8
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)