

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P761878

Luminaire Tested: LD6D20D010-EU6DR1015209030-6LBS1B

Issue Date: 2/2/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P761878  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2310-195-4)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/2/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD6D20D010-EU6DR1015209030-6LBS1B  
Description: 6 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 10° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1882.6 lumens  
Efficiency: N/A  
Efficacy: 81.5 lumens/watt  
Spacing Criteria (0/90/45): 0.17 / 0.17 / 0.18  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct

Input Watts (W): 23.1  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight



TEST NUMBER: P761878

CATALOG NUMBER: LD6D20D010-EU6DR1015209030-6LBS1B

### Luminous Intensity Polar Plot





TEST NUMBER: P761878

CATALOG NUMBER: LD6D20D010-EU6DR1015209030-6LBS1B

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |  |     |     |     |     |  |     |     |     |  |     |     |     |  |     |     |     |
|-----|-----|-----|-----|-----|--|-----|-----|-----|-----|--|-----|-----|-----|--|-----|-----|-----|--|-----|-----|-----|
| RF  | 20  |     |     |     |  | 20  |     |     |     |  | 20  |     |     |  |     | 20  |     |  |     |     | 20  |
| RC  | 80  |     |     |     |  | 70  |     |     |     |  | 50  |     |     |  |     | 30  |     |  |     |     | 10  |
| RW  | 70  | 50  | 30  | 10  |  | 70  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  | 30  | 10  |
| RCR |     |     |     |     |  |     |     |     |     |  |     |     |     |  |     |     |     |  |     |     |     |
| 0   | 119 | 119 | 119 | 119 |  | 116 | 116 | 116 | 116 |  | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 | 102 | 102 |
| 1   | 116 | 114 | 113 | 111 |  | 114 | 112 | 111 | 109 |  | 108 | 107 | 106 |  | 104 | 104 | 103 |  | 101 | 101 | 100 |
| 2   | 113 | 110 | 108 | 106 |  | 111 | 108 | 106 | 104 |  | 105 | 104 | 102 |  | 103 | 101 | 100 |  | 100 | 99  | 98  |
| 3   | 111 | 107 | 104 | 102 |  | 109 | 106 | 103 | 101 |  | 103 | 101 | 99  |  | 101 | 99  | 98  |  | 99  | 98  | 96  |
| 4   | 108 | 104 | 101 | 99  |  | 107 | 103 | 100 | 98  |  | 101 | 99  | 97  |  | 99  | 97  | 96  |  | 98  | 96  | 95  |
| 5   | 106 | 102 | 99  | 96  |  | 105 | 101 | 98  | 96  |  | 99  | 97  | 95  |  | 98  | 96  | 94  |  | 97  | 95  | 94  |
| 6   | 104 | 100 | 96  | 94  |  | 103 | 99  | 96  | 94  |  | 98  | 95  | 93  |  | 97  | 94  | 93  |  | 96  | 94  | 92  |
| 7   | 103 | 98  | 95  | 93  |  | 102 | 97  | 94  | 92  |  | 96  | 94  | 92  |  | 95  | 93  | 92  |  | 95  | 93  | 91  |
| 8   | 101 | 96  | 93  | 91  |  | 100 | 96  | 93  | 91  |  | 95  | 92  | 91  |  | 94  | 92  | 90  |  | 93  | 92  | 90  |
| 9   | 100 | 95  | 92  | 90  |  | 99  | 94  | 92  | 90  |  | 94  | 91  | 90  |  | 93  | 91  | 89  |  | 93  | 91  | 89  |
| 10  | 98  | 94  | 91  | 89  |  | 98  | 93  | 91  | 89  |  | 93  | 90  | 88  |  | 92  | 90  | 88  |  | 92  | 90  | 88  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |         |
|-----|---------|
|     | 0°      |
| 0°  | 4478587 |
| 5°  | 2123730 |
| 10° | 435553  |
| 15° | 119574  |
| 20° | 48195   |
| 25° | 25823   |
| 30° | 15278   |
| 35° | 9937    |
| 40° | 6647    |
| 45° | 4311    |
| 50° | 2380    |
| 55° | 1772    |
| 60° | 1027    |
| 65° | 0       |
| 70° | 0       |
| 75° | 0       |
| 80° | 0       |
| 85° | 0       |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4311 cd/sqm



TEST NUMBER: P761878

CATALOG NUMBER: LD6D20D010-EU6DR1015209030-6LBS1B

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 1338.6 | 71.1      |
| 10°-20°   | 362.2  | 19.2      |
| 20°-30°   | 103.7  | 5.5       |
| 30°-40°   | 47.4   | 2.5       |
| 40°-50°   | 21.7   | 1.2       |
| 50°-60°   | 7.2    | 0.4       |
| 60°-70°   | 1.7    | 0.1       |
| 70°-80°   | 0.0    | 0.0       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 1804.6 | 95.9      |
| 0°-40°    | 1851.9 | 98.4      |
| 0°-60°    | 1880.9 | 99.9      |
| 0°-90°    | 1882.6 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 1882.6 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°    | Flux |
|-----|-------|------|
| 0°  | 40990 |      |
| 5°  | 19363 | ###  |
| 15° | 1057  | 362  |
| 25° | 214   | 104  |
| 35° | 74    | 47   |
| 45° | 28    | 22   |
| 55° | 9     | 7    |
| 65° | 0     | 2    |
| 75° | 0     | 0    |
| 85° | 0     | 0    |
| 90° | 0     |      |

TEST NUMBER: P761878

CATALOG NUMBER: LD6D20D010-EU6DR1015209030-6LBS1B

**CANDELA DISTRIBUTION (FULL):**

|       | 0°      |
|-------|---------|
| 0°    | 40989.9 |
| 0.5°  | 40635.9 |
| 1°    | 39727.8 |
| 1.5°  | 37976.9 |
| 2°    | 36016.3 |
| 2.5°  | 33427.1 |
| 3°    | 30549.1 |
| 3.5°  | 27764.3 |
| 4°    | 24760.6 |
| 4.5°  | 21994.4 |
| 5°    | 19363.3 |
| 5.5°  | 16979.0 |
| 6°    | 14706.4 |
| 6.5°  | 12708.6 |
| 7°    | 10827.2 |
| 7.5°  | 9220.6  |
| 8°    | 7795.6  |
| 8.5°  | 6547.6  |
| 9°    | 5467.2  |
| 9.5°  | 4642.9  |
| 10°   | 3925.8  |
| 12.5° | 1872.1  |
| 15°   | 1057.1  |
| 17.5° | 642.6   |
| 20°   | 414.5   |
| 22.5° | 288.7   |
| 25°   | 214.2   |
| 27.5° | 158.3   |
| 30°   | 121.1   |
| 32.5° | 93.1    |
| 35°   | 74.5    |
| 37.5° | 55.9    |
| 40°   | 46.6    |
| 42.5° | 37.3    |
| 45°   | 27.9    |
| 47.5° | 18.6    |
| 50°   | 14.0    |
| 52.5° | 9.3     |
| 55°   | 9.3     |
| 57.5° | 4.7     |
| 60°   | 4.7     |
| 62.5° | 4.7     |
| 65°   | 0.0     |



TEST NUMBER: P761878

CATALOG NUMBER: LD6D20D010-EU6DR1015209030-6LBS1B

CANDELA DISTRIBUTION (continued):

|       | 0°  |
|-------|-----|
| 72.5° | 0.0 |
| 75°   | 0.0 |
| 77.5° | 0.0 |
| 80°   | 0.0 |
| 82.5° | 0.0 |
| 85°   | 0.0 |
| 87.5° | 0.0 |
| 90°   | 0.0 |



Report Generated By 670245859 / DESKTOP-T8S5UU9





— 0°-180°







|       |     |
|-------|-----|
| 67.5° | 0.0 |
| 70°   | 0.0 |



(END OF REPORT)