

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P774580

Luminaire Tested: LD6D95BD010-EU6DR5570959027-6LBS1H

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P774580
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-52)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D95BD010-EU6DR5570959027-6LBS1H
Description: 6 INCH ROUND SHALLOW SEMI-SPECULAR CLEAR TRIM, WITH 55° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 11681.5 lumens
Efficiency: N/A
Efficacy: 117.8 lumens/watt
Spacing Criteria (0/90/45): 0.89 / 0.89 / 0.87
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 99.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P774580

CATALOG NUMBER: LD6D95BD010-EU6DR5570959027-6LBS1H

Luminous Intensity Polar Plot





TEST NUMBER: P774580

CATALOG NUMBER: LD6D95BD010-EU6DR5570959027-6LBS1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	108	106	111	109	106	104	105	103	101		101	99	98		97
2	108	103	99	96	106	101	98	95	98	95	92		95	93	90		92
3	102	96	91	87	100	95	90	86	92	88	85		90	86	84		87
4	97	90	84	80	95	88	83	79	86	82	78		84	81	78		82
5	92	84	78	74	91	83	77	73	81	76	73		79	75	72		78
6	88	79	73	68	86	78	72	68	76	71	68		75	70	67		74
7	83	74	68	64	82	73	67	63	72	67	63		71	66	63		70
8	79	69	63	59	78	69	63	59	68	63	59		67	62	59		66
9	75	66	60	56	74	65	59	55	64	59	55		63	58	55		62
10	72	62	56	52	71	61	56	52	61	56	52		60	55	52		59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1431196
5°	1374354
10°	1369177
15°	1329848
20°	1192390
25°	985448
30°	744390
35°	539733
40°	345421
45°	157763
50°	51589
55°	22268
60°	9571
65°	1267
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 157763 cd/sqm

TEST NUMBER: P774580

CATALOG NUMBER: LD6D95BD010-EU6DR5570959027-6LBS1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1192.4	10.2
10°-20°	3254.2	27.9
20°-30°	3708.5	31.7
30°-40°	2524.6	21.6
40°-50°	870.0	7.4
50°-60°	120.3	1.0
60°-70°	11.6	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	8155.1	69.8
0°-40°	10679.6	91.4
0°-60°	11669.9	99.9
0°-90°	11681.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	11681.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	13099	
5°	12531	###
15°	11757	3254
25°	8174	3708
35°	4046	2525
45°	1021	870
55°	117	120
65°	5	12
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P774580

CATALOG NUMBER: LD6D95BD010-EU6DR5570959027-6LBS1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	13098.9
2.5°	12798.6
5°	12530.8
7.5°	12399.3
10°	12340.9
12.5°	12146.1
15°	11756.6
17.5°	11138.1
20°	10255.1
22.5°	9235.8
25°	8174.2
27.5°	7068.9
30°	5900.2
32.5°	4910.1
35°	4046.5
37.5°	3225.2
40°	2421.8
42.5°	1678.4
45°	1021.0
47.5°	550.3
50°	303.5
52.5°	180.2
55°	116.9
57.5°	74.7
60°	43.8
62.5°	19.5
65°	4.9
67.5°	1.6
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)