

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P774373

Luminaire Tested: LD6D95BD010-EU6DR4070959035-6LBS1LI

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P774373
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-28)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D95BD010-EU6DR4070959035-6LBS1LI
Description: 6 INCH ROUND SHALLOW SPECULAR CLEAR TRIM, WITH 40° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 13036.2 lumens
Efficiency: N/A
Efficacy: 131.4 lumens/watt
Spacing Criteria (0/90/45): 0.68 / 0.68 / 0.6
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 99.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P774373

CATALOG NUMBER: LD6D95BD010-EU6DR4070959035-6LBS1LI

Luminous Intensity Polar Plot





TEST NUMBER: P774373

CATALOG NUMBER: LD6D95BD010-EU6DR4070959035-6LBS1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	115	112	110	108	112	110	108	107	106	105	103	103	101	100	99	98	97	96		
2	110	106	103	100	108	105	102	99	102	99	97	99	97	95	96	95	93	92		
3	106	101	97	94	104	100	96	93	97	94	92	95	93	90	93	91	89	88		
4	102	97	92	89	101	95	91	88	93	90	87	92	89	86	90	87	85	84		
5	99	92	88	84	97	91	87	84	90	86	83	88	85	83	87	84	82	81		
6	95	88	84	80	94	88	83	80	86	82	80	85	82	79	84	81	79	77		
7	92	85	80	77	91	84	80	77	83	79	76	82	79	76	81	78	76	74		
8	89	82	77	74	88	81	77	74	80	76	73	79	76	73	78	75	73	72		
9	86	79	74	71	85	78	74	71	77	73	71	76	73	70	76	72	70	69		
10	83	76	71	68	82	75	71	68	75	71	68	74	70	68	73	70	68	67		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	3316250
5°	3300127
10°	3119343
15°	2651835
20°	1807415
25°	754125
30°	237124
35°	110214
40°	60946
45°	27952
50°	13564
55°	7429
60°	3868
65°	1370
70°	575
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 27952 cd/sqm



TEST NUMBER: P774373

CATALOG NUMBER: LD6D95BD010-EU6DR4070959035-6LBS1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	2809.6	21.6
10°-20°	6294.2	48.3
20°-30°	3150.7	24.2
30°-40°	577.6	4.4
40°-50°	159.4	1.2
50°-60°	37.4	0.3
60°-70°	7.1	0.1
70°-80°	0.2	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	12254.4	94.0
0°-40°	12832.0	98.4
0°-60°	13028.8	99.9
0°-90°	13036.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	13036.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	30352	
5°	30089	###
15°	23444	6294
25°	6255	3151
35°	826	578
45°	181	159
55°	39	37
65°	5	7
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P774373

CATALOG NUMBER: LD6D95BD010-EU6DR4070959035-6LBS1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	30351.7
2.5°	30307.3
5°	30089.2
7.5°	29394.2
10°	28115.8
12.5°	26122.9
15°	23443.7
17.5°	19959.6
20°	15544.6
22.5°	10597.7
25°	6255.4
27.5°	3306.8
30°	1879.5
32.5°	1214.6
35°	826.3
37.5°	590.4
40°	427.3
42.5°	292.6
45°	180.9
47.5°	115.3
50°	79.8
52.5°	56.7
55°	39.0
57.5°	24.8
60°	17.7
62.5°	10.6
65°	5.3
67.5°	3.5
70°	1.8
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9





— 0°-180°







(END OF REPORT)