

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P774464

Luminaire Tested: LD6D95BD010-EU6DR4570959040-6LBS1LI

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P774464
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-36)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D95BD010-EU6DR4570959040-6LBS1LI
Description: 6 INCH ROUND SHALLOW SPECULAR CLEAR TRIM, WITH 45° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 13387.8 lumens
Efficiency: N/A
Efficacy: 135.0 lumens/watt
Spacing Criteria (0/90/45): 0.75 / 0.75 / 0.69
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 99.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P774464

CATALOG NUMBER: LD6D95BD010-EU6DR4570959040-6LBS1LI

Luminous Intensity Polar Plot



TEST NUMBER: P774464

CATALOG NUMBER: LD6D95BD010-EU6DR4570959040-6LBS1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	112	110	108	112	110	108	106	106	104	103		102	101	100		98
2	109	105	102	99	107	103	100	98	100	98	95		97	95	93		95
3	105	99	95	91	103	98	94	91	95	92	89		93	90	88		91
4	100	94	89	85	99	93	88	85	91	87	84		89	86	83		87
5	96	89	84	80	95	88	83	80	86	82	79		85	81	79		83
6	92	85	80	76	91	84	79	76	83	78	75		81	77	75		80
7	89	81	75	72	87	80	75	72	79	74	71		78	74	71		77
8	85	77	72	68	84	76	71	68	75	71	68		74	70	67		73
9	82	73	68	65	81	73	68	65	72	68	65		71	67	64		71
10	79	70	65	62	78	70	65	62	69	65	62		68	64	61		68

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2585459
5°	2511848
10°	2403163
15°	2199398
20°	1744884
25°	1089355
30°	600424
35°	269607
40°	106188
45°	50033
50°	23729
55°	12401
60°	6097
65°	1448
70°	607
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 50033 cd/sqm



TEST NUMBER: P774464

CATALOG NUMBER: LD6D95BD010-EU6DR4570959040-6LBS1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	2151.9	16.1
10°-20°	5296.0	39.6
20°-30°	4193.9	31.3
30°-40°	1396.6	10.4
40°-50°	277.2	2.1
50°-60°	62.9	0.5
60°-70°	9.1	0.1
70°-80°	0.2	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	11641.7	87.0
0°-40°	13038.4	97.4
0°-60°	13378.5	99.9
0°-90°	13387.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	13387.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	23663	
5°	22902	###
15°	19444	5296
25°	9036	4194
35°	2021	1397
45°	324	277
55°	65	63
65°	6	9
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P774464

CATALOG NUMBER: LD6D95BD010-EU6DR4570959040-6LBS1LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	23663.2
2.5°	23508.7
5°	22902.0
7.5°	22401.3
10°	21660.6
12.5°	20674.1
15°	19443.9
17.5°	17593.9
20°	15006.8
22.5°	11924.7
25°	9036.1
27.5°	6616.5
30°	4759.1
32.5°	3236.6
35°	2021.3
37.5°	1198.6
40°	744.5
42.5°	489.5
45°	323.8
47.5°	208.5
50°	139.6
52.5°	93.1
55°	65.1
57.5°	42.8
60°	27.9
62.5°	14.9
65°	5.6
67.5°	1.9
70°	1.9
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)