

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P202929

Luminaire Tested: **LD6B20D010 EU6B10208040 6LBWGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P202929
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B20D010 EU6B10208040 6LBWGPH1
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT
WIDE DISTRIBUTIONWITH GRAPHITE HAZE TRIM
WATTAGE D010TR-21.86 W DE010-20.46 W D5LT-21.24 W DMX-20.89 W DL2-22.5 W
DL3-21.8 6 W DLE-22.46 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1405.1 lumens
Efficiency: N/A
Efficacy: 67.6 lumens/watt
Spacing Criteria (0/90/45): 1.11 / 1.11 / 1.11
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 20.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P202929

CATALOG NUMBER: LD6B20D010 EU6B10208040 6LBWGPH1

Luminous Intensity Polar Plot






TEST NUMBER: P202929

CATALOG NUMBER: LD6B20D010 EU6B10208040 6LBWGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	98	96		96
2	106	100	95	91	103	98	94	90	95	91	88		92	89	86		89
3	99	91	85	81	97	90	84	80	87	82	79		85	81	77		82
4	93	84	77	72	91	82	76	72	80	75	71		78	74	70		76
5	87	77	70	65	85	76	69	65	74	68	64		72	67	63		71
6	81	71	64	59	80	70	63	59	68	62	58		67	62	58		65
7	76	65	58	53	75	65	58	53	63	57	53		62	57	53		61
8	72	61	54	49	70	60	53	49	59	53	49		58	52	48		57
9	68	57	50	45	66	56	49	45	55	49	45		54	48	45		53
10	64	53	46	42	63	52	46	42	51	45	41		51	45	41		50

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P202929

CATALOG NUMBER: LD6B20D010 EU6B10208040 6LBWGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	90.0	6.4
10°-20°	252.3	18.0
20°-30°	361.0	25.7
30°-40°	359.8	25.6
40°-50°	229.2	16.3
50°-60°	84.5	6.0
60°-70°	21.1	1.5
70°-80°	6.4	0.5
80°-90°	1.0	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	703.2	50.0
0°-40°	1063.0	75.7
0°-60°	1376.7	98.0
0°-90°	1405.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1405.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	955	
5°	950	90
15°	897	252
25°	788	361
35°	585	360
45°	295	229
55°	90	84
65°	19	21
75°	5	6
85°	0	1
90°	0	



TEST NUMBER: P202929

CATALOG NUMBER: LD6B20D010 EU6B10208040 6LBWGPH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	955.0
2.5°	955.0
5°	950.2
7.5°	940.5
10°	928.4
12.5°	913.9
15°	897.0
17.5°	875.2
20°	851.1
22.5°	824.5
25°	788.2
27.5°	749.5
30°	698.7
32.5°	645.6
35°	585.1
37.5°	512.6
40°	437.6
42.5°	365.1
45°	295.0
47.5°	232.1
50°	174.1
52.5°	128.1
55°	89.5
57.5°	58.0
60°	38.7
62.5°	26.6
65°	19.3
67.5°	14.5
70°	12.1
72.5°	7.3
75°	4.8
77.5°	4.8
80°	2.4
82.5°	2.4
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)