

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P252799

Luminaire Tested: **LD6B30D010 EU6B30509035 6LBBA1MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P252799
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1712-453-2)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B30D010 EU6B30509035 6LBBA1MW
Description: PORTFOLIO 6 INCH BAFFLE RECESSED DOWNLIGHT, WITH MATTE WHITE TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3257.0 lumens
Efficiency: N/A
Efficacy: 116.3 lumens/watt
Spacing Criteria (0/90/45): 1.03 / 1.03 / 1
Luminous Opening: Circular (Dia: 0.46' x H: 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P252799

CATALOG NUMBER: LD6B30D010 EU6B30509035 6LBBA1MW

Luminous Intensity Polar Plot





TEST NUMBER: P252799

CATALOG NUMBER: LD6B30D010 EU6B30509035 6LBBA1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	111	107	104	101	108	105	102	99	101	98	96		97	95	93		94
2	103	97	91	87	101	95	90	86	91	87	84		88	85	82		85
3	96	87	81	76	94	86	80	75	83	78	74		81	76	72		78
4	90	80	72	67	87	78	72	66	76	70	66		74	69	65		72
5	84	73	65	60	82	72	65	60	70	64	59		68	63	58		66
6	78	67	60	54	77	66	59	54	65	58	54		63	57	53		62
7	74	62	55	49	72	61	54	49	60	53	49		59	53	49		57
8	69	58	50	45	68	57	50	45	56	49	45		55	49	45		53
9	65	54	46	42	64	53	46	42	52	46	41		51	45	41		50
10	62	50	43	39	61	50	43	39	49	43	38		48	42	38		47

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	145741
5°	144405
10°	141226
15°	136739
20°	131218
25°	123181
30°	106589
35°	82989
40°	63082
45°	49168
50°	40781
55°	36603
60°	33325
65°	30751
70°	28250
75°	26190
80°	23669
85°	21633



TEST NUMBER: P252799

CATALOG NUMBER: LD6B30D010 EU6B30509035 6LBBA1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	208.1	6.4
10°-20°	568.8	17.5
20°-30°	774.7	23.8
30°-40°	655.5	20.1
40°-50°	420.5	12.9
50°-60°	289.4	8.9
60°-70°	197.7	6.1
70°-80°	110.0	3.4
80°-90°	32.2	1.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1551.7	47.6
0°-40°	2207.2	67.8
0°-60°	2917.1	89.6
0°-90°	3257.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3257.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2234	
5°	2205	208
15°	2024	569
25°	1711	775
35°	1042	656
45°	533	421
55°	322	289
65°	199	198
75°	104	110
85°	29	32
90°	0	



TEST NUMBER: P252799

CATALOG NUMBER: LD6B30D010 EU6B30509035 6LBBA1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	2233.9
2.5°	2225.4
5°	2205.0
7.5°	2172.6
10°	2131.8
12.5°	2080.7
15°	2024.5
17.5°	1959.8
20°	1890.0
22.5°	1811.7
25°	1711.2
27.5°	1575.0
30°	1414.9
32.5°	1231.0
35°	1042.0
37.5°	876.9
40°	740.7
42.5°	626.6
45°	532.9
47.5°	459.7
50°	401.8
52.5°	357.6
55°	321.8
57.5°	287.8
60°	255.4
62.5°	226.5
65°	199.2
67.5°	172.0
70°	148.1
72.5°	124.3
75°	103.9
77.5°	83.4
80°	63.0
82.5°	46.0
85°	28.9
87.5°	11.9
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)