

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203046

Luminaire Tested: **LD6B30D010 EU6B30508050 6LBWB1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203046
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B30D010 EU6B30508050 6LBWB1
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT
WIDE DISTRIBUTION WITH SPECULAR BLACK TRIM
WATTAGE D010TR-27.4 W DE010-27.95 W D5LT-27.65 W DMX-27.73 W DL2-29.56 W
DL3-29.67 W DLE-29.73 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1720.9 lumens
Efficiency: N/A
Efficacy: 61.5 lumens/watt
Spacing Criteria (0/90/45): 1.08 / 1.08 / 1.08
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203046

CATALOG NUMBER: LD6B30D010 EU6B30508050 6LBWB1

Luminous Intensity Polar Plot






TEST NUMBER: P203046

CATALOG NUMBER: LD6B30D010 EU6B30508050 6LBWB1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20				20
RC	80				70					50					30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30
RCR																			
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	96	95	94	92	92
2	106	101	97	93	104	99	95	92	96	93	90	93	90	88	90	88	86	84	84
3	100	93	87	83	98	92	86	82	89	85	81	86	83	80	84	81	78	77	77
4	94	86	79	75	92	85	79	74	82	77	73	80	76	73	78	75	72	70	70
5	89	79	73	68	87	78	72	67	76	71	67	75	70	66	73	69	66	64	64
6	83	73	67	62	82	72	66	61	71	65	61	69	64	61	68	64	60	59	59
7	78	68	61	56	77	67	61	56	66	60	56	65	60	56	63	59	55	54	54
8	74	63	57	52	73	63	56	52	61	56	52	60	55	51	59	55	51	50	50
9	70	59	52	48	69	58	52	48	57	52	48	57	51	47	56	51	47	46	46
10	66	55	49	44	65	55	49	44	54	48	44	53	48	44	52	47	44	42	42

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203046

CATALOG NUMBER: LD6B30D010 EU6B30508050 6LBWB1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	121.9	7.1
10°-20°	341.0	19.8
20°-30°	477.7	27.8
30°-40°	456.2	26.5
40°-50°	259.8	15.1
50°-60°	63.5	3.7
60°-70°	0.8	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	940.6	54.7
0°-40°	1396.8	81.2
0°-60°	1720.1	100.0
0°-90°	1720.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1720.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1297	
5°	1286	122
15°	1209	341
25°	1045	478
35°	743	456
45°	333	260
55°	63	63
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P203046

CATALOG NUMBER: LD6B30D010 EU6B30508050 6LBWB1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1297.0
2.5°	1297.0
5°	1286.5
7.5°	1272.5
10°	1261.9
12.5°	1240.9
15°	1209.4
17.5°	1181.3
20°	1146.3
22.5°	1100.7
25°	1044.6
27.5°	981.5
30°	911.4
32.5°	827.3
35°	743.1
37.5°	641.5
40°	532.8
42.5°	431.2
45°	333.0
47.5°	245.4
50°	171.8
52.5°	108.7
55°	63.1
57.5°	28.0
60°	7.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)