

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P204515

Luminaire Tested: **LD6B50D010TE EU6B30509024 6LBSB1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204515
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B50D010TE EU6B30509024 6LBSB1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH SPECULAR BLACK TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3535.7 lumens
Efficiency: N/A
Efficacy: 60.2 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.2 / 1.3
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.77
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204515

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBSB1

Luminous Intensity Polar Plot





TEST NUMBER: P204515

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBSB1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	111	107	103	100	108	105	101	98	100	98	95	97	94	93	93	91	90	88		
2	102	95	89	84	100	93	88	83	90	85	81	86	83	79	84	80	78	76		
3	94	84	77	72	91	83	76	71	80	74	70	77	73	68	75	71	67	65		
4	86	76	68	62	84	74	67	61	72	65	60	70	64	60	68	63	59	57		
5	80	68	60	54	78	67	59	53	65	58	53	63	57	52	61	56	52	50		
6	74	62	53	47	72	61	53	47	59	52	47	57	51	46	56	50	46	44		
7	69	56	48	42	67	55	48	42	54	47	42	52	46	41	51	45	41	39		
8	64	51	43	38	63	51	43	38	49	42	37	48	42	37	47	41	37	35		
9	60	47	39	34	59	47	39	34	46	39	34	45	38	34	44	38	34	32		
10	56	44	36	31	55	43	36	31	42	36	31	41	35	31	40	35	31	29		

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204515

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBSB1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	147.2	4.2
10°-20°	417.7	11.8
20°-30°	621.3	17.6
30°-40°	723.0	20.4
40°-50°	704.7	19.9
50°-60°	542.1	15.3
60°-70°	299.7	8.5
70°-80°	79.4	2.2
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1186.2	33.6
0°-40°	1909.3	54.0
0°-60°	3156.1	89.3
0°-90°	3535.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3535.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1560	
5°	1551	147
15°	1479	418
25°	1349	621
35°	1161	723
45°	914	705
55°	605	542
65°	300	300
75°	67	79
85°	0	1
90°	0	



TEST NUMBER: P204515

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBSB1

CANDELA DISTRIBUTION (FULL):

0°	
0°	1559.7
2.5°	1559.7
5°	1550.7
7.5°	1537.3
10°	1528.3
12.5°	1501.4
15°	1479.0
17.5°	1456.6
20°	1425.2
22.5°	1393.9
25°	1349.1
27.5°	1304.2
30°	1259.4
32.5°	1210.1
35°	1160.8
37.5°	1098.1
40°	1044.3
42.5°	986.0
45°	914.3
47.5°	847.1
50°	770.9
52.5°	690.2
55°	605.1
57.5°	524.4
60°	448.2
62.5°	372.0
65°	300.3
67.5°	233.1
70°	170.3
72.5°	116.5
75°	67.2
77.5°	31.4
80°	4.5
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)