

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P205541

Luminaire Tested: **LD6B50D010TE EU6B30509027 6LBMGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205541
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B50D010TE EU6B30509027 6LBMGPH1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH GRAPHITE HAZE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2449.5 lumens
Efficiency: N/A
Efficacy: 41.7 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.91
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.77
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205541

CATALOG NUMBER: LD6B50D010TE EU6B30509027 6LBMGPH1

Luminous Intensity Polar Plot






TEST NUMBER: P205541

CATALOG NUMBER: LD6B50D010TE EU6B30509027 6LBMGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	108	105	111	108	106	104	104	102	101		100	99	98		97
2	107	102	98	94	105	100	97	93	97	94	91		94	92	89		91
3	102	95	90	85	100	93	89	85	91	87	83		88	85	82		86
4	96	88	82	78	94	87	82	77	85	80	77		83	79	76		81
5	91	82	76	72	89	81	76	71	79	74	71		78	73	70		76
6	86	77	71	66	85	76	70	66	74	69	65		73	68	65		72
7	82	72	66	61	80	71	65	61	70	65	61		69	64	60		68
8	77	68	61	57	76	67	61	57	66	60	57		65	60	56		64
9	74	64	57	53	72	63	57	53	62	57	53		61	56	53		60
10	70	60	54	50	69	59	54	50	59	53	50		58	53	49		57

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205541

CATALOG NUMBER: LD6B50D010TE EU6B30509027 6LBMGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	234.5	9.6
10°-20°	608.5	24.8
20°-30°	775.3	31.7
30°-40°	547.9	22.4
40°-50°	200.0	8.2
50°-60°	55.4	2.3
60°-70°	20.1	0.8
70°-80°	7.1	0.3
80°-90°	0.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1618.3	66.1
0°-40°	2166.2	88.4
0°-60°	2421.6	98.9
0°-90°	2449.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2449.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2553	
5°	2508	234
15°	2167	608
25°	1722	775
35°	871	548
45°	242	200
55°	59	55
65°	20	20
75°	5	7
85°	0	1
90°	0	



TEST NUMBER: P205541

CATALOG NUMBER: LD6B50D010TE EU6B30509027 6LBMGPH1

CANDELA DISTRIBUTION (FULL):

0°	
0°	2552.6
2.5°	2542.7
5°	2508.1
7.5°	2438.8
10°	2364.6
12.5°	2265.7
15°	2166.8
17.5°	2067.8
20°	1968.9
22.5°	1850.2
25°	1721.5
27.5°	1543.4
30°	1345.6
32.5°	1108.1
35°	870.7
37.5°	662.9
40°	484.8
42.5°	351.2
45°	242.4
47.5°	163.2
50°	108.8
52.5°	74.2
55°	59.4
57.5°	44.5
60°	34.6
62.5°	24.7
65°	19.8
67.5°	14.8
70°	9.9
72.5°	9.9
75°	4.9
77.5°	4.9
80°	4.9
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)