

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P202555

Luminaire Tested: **LD6B50D010TE EU6B30508035 6LBSWMH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P202555
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B50D010TE EU6B30508035 6LBSWMH1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH WARM HAZE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5761.1 lumens
Efficiency: N/A
Efficacy: 98.0 lumens/watt
Spacing Criteria (0/90/45): 0.97 / 0.97 / 1.1
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.77
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P202555

CATALOG NUMBER: LD6B50D010TE EU6B30508035 6LBSWMH1

Luminous Intensity Polar Plot





TEST NUMBER: P202555

CATALOG NUMBER: LD6B50D010TE EU6B30508035 6LBSWMH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	111	107	104	101		108	105	102	99		101	98	96		97	95	93		94	92	90
2	103	96	90	85		100	94	89	84		91	86	82		87	84	81		84	81	79
3	95	86	79	73		92	84	78	73		81	76	71		79	74	70		76	72	69
4	88	77	70	64		86	76	69	63		74	67	62		71	66	62		69	65	61
5	81	70	62	56		79	69	61	56		67	60	55		65	59	55		63	58	54
6	76	64	56	50		74	63	55	50		61	54	49		59	53	49		58	53	48
7	70	58	50	45		69	57	50	45		56	49	44		55	48	44		53	48	44
8	66	54	46	40		64	53	45	40		52	45	40		50	44	40		49	44	40
9	62	49	42	37		61	49	42	37		48	41	37		47	41	36		46	40	36
10	58	46	39	34		57	45	38	34		45	38	34		44	38	33		43	37	33

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P202555

CATALOG NUMBER: LD6B50D010TE EU6B30508035 6LBSWMH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	308.2	5.4
10°-20°	805.7	14.0
20°-30°	1068.4	18.5
30°-40°	1139.6	19.8
40°-50°	1065.2	18.5
50°-60°	812.2	14.1
60°-70°	441.8	7.7
70°-80°	118.5	2.1
80°-90°	1.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2182.3	37.9
0°-40°	3321.9	57.7
0°-60°	5199.4	90.2
0°-90°	5761.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5761.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3332	
5°	3286	308
15°	2873	806
25°	2326	1068
35°	1821	1140
45°	1387	1065
55°	914	812
65°	441	442
75°	102	119
85°	0	1
90°	0	



TEST NUMBER: P202555

CATALOG NUMBER: LD6B50D010TE EU6B30508035 6LBSWMH1

CANDELA DISTRIBUTION (FULL):

0°	
0°	3331.5
2.5°	3320.9
5°	3285.6
7.5°	3211.5
10°	3126.8
12.5°	3006.8
15°	2872.7
17.5°	2738.6
20°	2593.9
22.5°	2456.2
25°	2325.7
27.5°	2188.0
30°	2057.5
32.5°	1930.4
35°	1821.0
37.5°	1711.6
40°	1598.7
42.5°	1496.3
45°	1386.9
47.5°	1266.9
50°	1154.0
52.5°	1034.0
55°	914.0
57.5°	783.5
60°	663.5
62.5°	550.5
65°	441.1
67.5°	342.3
70°	250.6
72.5°	172.9
75°	102.3
77.5°	45.9
80°	10.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)