

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P205545

Luminaire Tested: **LD6B50D010TE EU6B30509050 6LBMGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205545
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B50D010TE EU6B30509050 6LBMGPH1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH GRAPHITE HAZE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2599.0 lumens
Efficiency: N/A
Efficacy: 44.2 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.91
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.77
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205545

CATALOG NUMBER: LD6B50D010TE EU6B30509050 6LBMGPH1

Luminous Intensity Polar Plot





TEST NUMBER: P205545

CATALOG NUMBER: LD6B50D010TE EU6B30509050 6LBMGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	108	105	111	108	106	104	104	102	101		100	99	98		97
2	107	102	98	94	105	100	97	93	97	94	91		94	92	89		91
3	102	95	90	85	100	93	89	85	91	87	83		88	85	82		86
4	96	88	82	78	94	87	82	77	85	80	77		83	79	76		81
5	91	82	76	72	89	81	76	71	79	74	71		78	73	70		76
6	86	77	71	66	85	76	70	66	74	69	65		73	68	65		72
7	82	72	66	61	80	71	65	61	70	65	61		69	64	60		68
8	77	68	61	57	76	67	61	57	66	60	57		65	60	56		64
9	74	64	57	53	72	63	57	53	62	57	53		61	56	53		60
10	70	60	54	50	69	59	54	50	59	53	50		58	53	49		57

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205545

CATALOG NUMBER: LD6B50D010TE EU6B30509050 6LBMGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	248.8	9.6
10°-20°	645.6	24.8
20°-30°	822.6	31.7
30°-40°	581.3	22.4
40°-50°	212.2	8.2
50°-60°	58.8	2.3
60°-70°	21.3	0.8
70°-80°	7.6	0.3
80°-90°	0.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1717.0	66.1
0°-40°	2298.4	88.4
0°-60°	2569.4	98.9
0°-90°	2599.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2599.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2708	
5°	2661	249
15°	2299	646
25°	1827	823
35°	924	581
45°	257	212
55°	63	59
65°	21	21
75°	5	8
85°	0	1
90°	0	



TEST NUMBER: P205545

CATALOG NUMBER: LD6B50D010TE EU6B30509050 6LBMGPH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2708.4
2.5°	2697.9
5°	2661.1
7.5°	2587.6
10°	2508.9
12.5°	2403.9
15°	2299.0
17.5°	2194.0
20°	2089.0
22.5°	1963.0
25°	1826.6
27.5°	1637.6
30°	1427.7
32.5°	1175.7
35°	923.8
37.5°	703.3
40°	514.4
42.5°	372.7
45°	257.2
47.5°	173.2
50°	115.5
52.5°	78.7
55°	63.0
57.5°	47.2
60°	36.7
62.5°	26.2
65°	21.0
67.5°	15.7
70°	10.5
72.5°	10.5
75°	5.2
77.5°	5.2
80°	5.2
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)