

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P136189

Luminaire Tested: **LD6A20D010TE ERW6A20930 6LW1H**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P136189
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P23374)
Test Lab: INNOVATION CENTER P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6A20D010TE ERW6A20930 6LW1H
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT
WIDE DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM
Light Source: (1) HIGH LUMEN LED 3000K
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2137.2 lumens
Efficiency: N/A
Efficacy: 65.2 lumens/watt
Spacing Criteria (0/90/45): 1.13 / 1.13 / 1.09
Luminous Opening: Circular (Dia: 0.46' x H: 0')
CIE Type: Direct


Input Watts (W): 32.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P136189

CATALOG NUMBER: LD6A20D010TE ERW6A20930 6LW1H

Luminous Intensity Polar Plot





TEST NUMBER: P136189

CATALOG NUMBER: LD6A20D010TE ERW6A20930 6LW1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	112	109	106	104	110	107	105	102	103	101	99	99	98	96	96	94	93	91		
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	87	84	83		
3	99	91	86	81	97	90	85	80	87	83	79	85	81	78	82	79	76	75		
4	93	84	77	72	91	83	77	72	80	75	71	78	74	70	76	73	69	68		
5	87	77	70	65	85	76	70	65	74	69	64	72	68	64	71	67	63	61		
6	82	71	64	59	80	70	64	59	69	63	58	67	62	58	66	61	58	56		
7	77	66	59	54	75	65	58	54	64	58	53	62	57	53	61	56	53	51		
8	72	61	54	49	71	61	54	49	59	53	49	58	53	49	57	52	49	47		
9	68	57	50	45	67	56	50	45	55	49	45	54	49	45	53	49	45	43		
10	64	53	46	42	63	53	46	42	52	46	42	51	46	42	50	45	42	40		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	96106
5°	95864
10°	94959
15°	94289
20°	92380
25°	88894
30°	82309
35°	70095
40°	53680
45°	37902
50°	25597
55°	16197
60°	9447
65°	4322
70°	2671
75°	1764
80°	864
85°	0



TEST NUMBER: P136189

CATALOG NUMBER: LD6A20D010TE ERW6A20930 6LW1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	138.7	6.5
10°-20°	392.6	18.4
20°-30°	564.4	26.4
30°-40°	542.8	25.4
40°-50°	323.2	15.1
50°-60°	133.3	6.2
60°-70°	33.5	1.6
70°-80°	7.7	0.4
80°-90°	0.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1095.8	51.3
0°-40°	1638.5	76.7
0°-60°	2095.1	98.0
0°-90°	2137.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2137.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1473	
5°	1464	139
15°	1396	393
25°	1235	564
35°	880	543
45°	411	323
55°	142	133
65°	28	34
75°	7	8
85°	0	1
90°	0	



TEST NUMBER: P136189

CATALOG NUMBER: LD6A20D010TE ERW6A20930 6LW1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	1473.1
2.5°	1466.1
5°	1463.8
7.5°	1452.1
10°	1433.4
12.5°	1414.7
15°	1396.0
17.5°	1368.1
20°	1330.6
22.5°	1286.3
25°	1234.9
27.5°	1172.0
30°	1092.6
32.5°	994.5
35°	880.1
37.5°	756.4
40°	630.3
42.5°	513.6
45°	410.8
47.5°	324.5
50°	252.2
52.5°	193.8
55°	142.4
57.5°	102.7
60°	72.4
62.5°	46.7
65°	28.0
67.5°	18.7
70°	14.0
72.5°	9.3
75°	7.0
77.5°	4.7
80°	2.3
82.5°	2.3
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)