

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P135471

Luminaire Tested: **LD6A20D010TE ERM6A20940 6LM1H**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P135471
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P23371)
Test Lab: INNOVATION CENTER P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6A20D010TE ERM6A20940 6LM1H
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM
Light Source: (1) HIGH LUMEN LED 4000K
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2070.8 lumens
Efficiency: N/A
Efficacy: 63.1 lumens/watt
Spacing Criteria (0/90/45): 0.92 / 0.92 / 0.9
Luminous Opening: Circular (Dia: 0.46' x H: 0')
CIE Type: Direct


Input Watts (W): 32.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P135471

CATALOG NUMBER: LD6A20D010TE ERM6A20940 6LM1H

Luminous Intensity Polar Plot





TEST NUMBER: P135471

CATALOG NUMBER: LD6A20D010TE ERM6A20940 6LM1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	111	108	106	111	108	106	104	104	102	101		101	99	98		97
2	108	103	98	95	105	101	97	94	98	94	92		95	92	90		92
3	102	95	90	86	100	94	89	85	91	87	84		89	86	83		87
4	97	89	83	79	95	88	82	78	85	81	77		83	80	76		82
5	91	83	77	73	90	82	76	72	80	75	72		78	74	71		77
6	87	78	71	67	85	77	71	67	75	70	66		74	69	66		73
7	82	73	67	62	81	72	66	62	71	66	62		70	65	61		68
8	78	68	62	58	77	68	62	58	67	61	58		66	61	57		65
9	74	64	58	54	73	64	58	54	63	58	54		62	57	54		61
10	71	61	55	51	70	60	55	51	60	54	51		59	54	51		58

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	147274
5°	144530
10°	137377
15°	128580
20°	118464
25°	107287
30°	88057
35°	57248
40°	30702
45°	16525
50°	9084
55°	4436
60°	2701
65°	1775
70°	1316
75°	580
80°	864
85°	0



TEST NUMBER: P135471

CATALOG NUMBER: LD6A20D010TE ERM6A20940 6LM1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	206.4	10.0
10°-20°	532.5	25.7
20°-30°	673.7	32.5
30°-40°	452.9	21.9
40°-50°	148.8	7.2
50°-60°	40.1	1.9
60°-70°	12.4	0.6
70°-80°	3.6	0.2
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1412.6	68.2
0°-40°	1865.5	90.1
0°-60°	2054.4	99.2
0°-90°	2070.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2070.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2257	
5°	2207	206
15°	1904	533
25°	1490	674
35°	719	453
45°	179	149
55°	39	40
65°	12	12
75°	2	4
85°	0	0
90°	0	



TEST NUMBER: P135471

CATALOG NUMBER: LD6A20D010TE ERM6A20940 6LM1H

CANDELA DISTRIBUTION (FULL):

	0°
0°	2257.4
2.5°	2236.7
5°	2206.9
7.5°	2151.8
10°	2073.7
12.5°	1991.0
15°	1903.7
17.5°	1805.0
20°	1706.3
22.5°	1605.2
25°	1490.4
27.5°	1350.3
30°	1168.9
32.5°	950.7
35°	718.8
37.5°	514.4
40°	360.5
42.5°	252.6
45°	179.1
47.5°	126.3
50°	89.5
52.5°	59.7
55°	39.0
57.5°	27.6
60°	20.7
62.5°	16.0
65°	11.5
67.5°	9.2
70°	6.9
72.5°	4.6
75°	2.3
77.5°	2.3
80°	2.3
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)