

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P136071

Luminaire Tested: **LD6A20D010TE ERW6A20940 6LW1LI**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P136071
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P23358)
Test Lab: INNOVATION CENTER P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6A20D010TE ERW6A20940 6LW1LI
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT
WIDE DISTRIBUTION WITH SPECULAR CLEAR TRIM
Light Source: (1) HIGH LUMEN LED 4000K
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2410.1 lumens
Efficiency: N/A
Efficacy: 73.5 lumens/watt
Spacing Criteria (0/90/45): 1.22 / 1.22 / 1.12
Luminous Opening: Circular (Dia: 0.46' x H: 0')
CIE Type: Direct


Input Watts (W): 32.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P136071

CATALOG NUMBER: LD6A20D010TE ERW6A20940 6LW1LI

Luminous Intensity Polar Plot





TEST NUMBER: P136071

CATALOG NUMBER: LD6A20D010TE ERW6A20940 6LW1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	107	105	110	108	105	103	104	102	100		100	98	97		97
2	107	101	97	93	104	99	95	92	96	93	90		93	90	88		90
3	100	93	88	83	98	92	87	83	89	85	81		87	83	80		84
4	94	86	80	75	93	85	79	75	83	78	74		81	76	73		79
5	89	80	73	68	87	79	73	68	77	71	67		75	70	67		73
6	84	74	67	62	82	73	67	62	71	66	62		70	65	61		69
7	79	68	62	57	77	68	61	57	66	61	57		65	60	56		64
8	74	64	57	53	73	63	57	52	62	56	52		61	56	52		60
9	70	60	53	49	69	59	53	48	58	52	48		57	52	48		56
10	66	56	49	45	65	55	49	45	54	49	45		54	48	45		53

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	101273
5°	103854
10°	110944
15°	119793
20°	121741
25°	114276
30°	100653
35°	81978
40°	59539
45°	38207
50°	20076
55°	6870
60°	1970
65°	509
70°	324
75°	429
80°	0
85°	0



TEST NUMBER: P136071

CATALOG NUMBER: LD6A20D010TE ERW6A20940 6LW1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	154.3	6.4
10°-20°	497.5	20.6
20°-30°	721.9	30.0
30°-40°	635.9	26.4
40°-50°	325.6	13.5
50°-60°	68.6	2.8
60°-70°	5.3	0.2
70°-80°	1.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1373.7	57.0
0°-40°	2009.5	83.4
0°-60°	2403.7	99.7
0°-90°	2410.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2410.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1552	
5°	1586	154
15°	1774	498
25°	1588	722
35°	1029	636
45°	414	326
55°	60	69
65°	3	5
75°	2	1
85°	0	0
90°	0	



TEST NUMBER: P136071

CATALOG NUMBER: LD6A20D010TE ERW6A20940 6LW1LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	1552.3
2.5°	1555.7
5°	1585.8
7.5°	1627.8
10°	1674.7
12.5°	1728.4
15°	1773.6
17.5°	1785.4
20°	1753.5
22.5°	1683.1
25°	1587.5
27.5°	1471.9
30°	1336.1
32.5°	1186.9
35°	1029.3
37.5°	865.0
40°	699.1
42.5°	549.9
45°	414.1
47.5°	296.7
50°	197.8
52.5°	115.7
55°	60.4
57.5°	30.1
60°	15.1
62.5°	6.7
65°	3.3
67.5°	3.3
70°	1.7
72.5°	1.7
75°	1.7
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)